

Hit Summary Sheet
SW-846

SDG No.:	Q2444	Order ID:	Q2444
Client:	Total Quality Environmental Inc.	Project ID:	Flushing Ave

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
Client ID : 1ST-PL-CHILD-CARE-SINK-2A								
Q2444-03	1ST-PL-CHILD-CARE-SINK-2/	Water	Lead	74.8		1.21	6.00	ug/L
Client ID : 1ST-PL-RESTROOM-2-CHILD-CARE-SINK-1								
Q2444-09	1ST-PL-RESTROOM-2-CHILD-	Water	Lead	8.73		1.21	6.00	ug/L
Client ID : 1ST-PL-RESTROOM-3-MENS-SINK-2								
Q2444-12	1ST-PL-RESTROOM-3-MENS-	Water	Lead	1.50	J	1.21	6.00	ug/L



SAMPLE DATA

A

B

C

D

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/27/25
Project:	Flushing Ave	Date Received:	06/27/25
Client Sample ID:	1ST-PL-CHILD-CARE-SINK-1A	SDG No.:	Q2444
Lab Sample ID:	Q2444-01	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	06/30/25 10:15	07/01/25 18:06	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/27/25
Project:	Flushing Ave	Date Received:	06/27/25
Client Sample ID:	1ST-PL-CHILD-CARE-SINK-1B	SDG No.:	Q2444
Lab Sample ID:	Q2444-02	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	06/30/25 10:15	07/01/25 18:15	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/27/25
Project:	Flushing Ave	Date Received:	06/27/25
Client Sample ID:	1ST-PL-CHILD-CARE-SINK-2A	SDG No.:	Q2444
Lab Sample ID:	Q2444-03	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	74.8	1	1.21		6.00	ug/L	06/30/25 10:15	07/01/25 18:19	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/27/25
Project:	Flushing Ave	Date Received:	06/27/25
Client Sample ID:	1ST-PL-CHILD-CARE-SINK-2B	SDG No.:	Q2444
Lab Sample ID:	Q2444-04	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	06/30/25 10:15	07/01/25 18:24	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/27/25
Project:	Flushing Ave	Date Received:	06/27/25
Client Sample ID:	1ST-PL-CHILD-CARE-RESTROOM-SINK-1A	SDG No.:	Q2444
Lab Sample ID:	Q2444-05	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	06/30/25 10:15	07/01/25 18:28	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/27/25
Project:	Flushing Ave	Date Received:	06/27/25
Client Sample ID:	1ST-PL-CHILD-CARE-RESTROOM-SINK-1B	SDG No.:	Q2444
Lab Sample ID:	Q2444-06	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	06/30/25 10:15	07/01/25 18:32	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/27/25
Project:	Flushing Ave	Date Received:	06/27/25
Client Sample ID:	1ST-PL-KITCHENSINK-1A	SDG No.:	Q2444
Lab Sample ID:	Q2444-07	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	06/30/25 10:15	07/01/25 18:45	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/27/25
Project:	Flushing Ave	Date Received:	06/27/25
Client Sample ID:	1ST-PL-KITCHENSINK-1B	SDG No.:	Q2444
Lab Sample ID:	Q2444-08	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	06/30/25 10:15	07/03/25 16:41	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/27/25
Project:	Flushing Ave	Date Received:	06/27/25
Client Sample ID:	1ST-PL-RESTROOM-2-CHILD-CARE-SINK-1	SDG No.:	Q2444
Lab Sample ID:	Q2444-09	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	8.73		1	1.21	6.00	ug/L	06/30/25 10:15	07/01/25 18:54	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/27/25
Project:	Flushing Ave	Date Received:	06/27/25
Client Sample ID:	1ST-PL-RESTROOM-2-CHILD-CARE-SINK-2	SDG No.:	Q2444
Lab Sample ID:	Q2444-10	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	06/30/25 10:15	07/01/25 18:58	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/27/25
Project:	Flushing Ave	Date Received:	06/27/25
Client Sample ID:	1ST-PL-RESTROOM-3-MENS-SINK-1	SDG No.:	Q2444
Lab Sample ID:	Q2444-11	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	06/30/25 10:15	07/01/25 19:02	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	06/27/25
Project:	Flushing Ave	Date Received:	06/27/25
Client Sample ID:	1ST-PL-RESTROOM-3-MENS-SINK-2	SDG No.:	Q2444
Lab Sample ID:	Q2444-12	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.50	J	1	1.21	6.00	ug/L	06/30/25 10:15	07/01/25 19:07	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group4			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

LAB CHRONICLE

OrderID:	Q2444	OrderDate:	6/27/2025 12:35:00 PM
Client:	Total Quality Environmental Inc.	Project:	Flushing Ave
Contact:	Alex Rukasov	Location:	D51

LabID	ClientID	Matrix	Test	Method	Sample Date	Prep Date	Anal Date	Received
Q2444-01	1ST-PL-CHILD-CARE-S INK-1A	Water			06/27/25			06/27/25
			Metals Group4	200.7		06/30/25	07/01/25	
Q2444-02	1ST-PL-CHILD-CARE-S INK-1B	Water			06/27/25			06/27/25
			Metals Group4	200.7		06/30/25	07/01/25	
Q2444-03	1ST-PL-CHILD-CARE-S INK-2A	Water			06/27/25			06/27/25
			Metals Group4	200.7		06/30/25	07/01/25	
Q2444-04	1ST-PL-CHILD-CARE-S INK-2B	Water			06/27/25			06/27/25
			Metals Group4	200.7		06/30/25	07/01/25	
Q2444-05	1ST-PL-CHILD-CARE- RESTROOM-SINK-1A	Water			06/27/25			06/27/25
			Metals Group4	200.7		06/30/25	07/01/25	
Q2444-06	1ST-PL-CHILD-CARE- RESTROOM-SINK-1B	Water			06/27/25			06/27/25
			Metals Group4	200.7		06/30/25	07/01/25	
Q2444-07	1ST-PL-KITCHENSINK -1A	Water			06/27/25			06/27/25
			Metals Group4	200.7		06/30/25	07/01/25	
Q2444-08	1ST-PL-KITCHENSINK -1B	Water			06/27/25			06/27/25
			Metals Group4	200.7		06/30/25	07/03/25	
Q2444-09	1ST-PL-RESTROOM-2- CHILD-CARE-SINK-1	Water			06/27/25			06/27/25
			Metals Group4	200.7		06/30/25	07/01/25	

LAB CHRONICLE

Q2444-10	1ST-PL-RESTROOM-2-CHILD-CARE-SINK-2	Water			06/27/25			06/27/25
			Metals Group4	200.7		06/30/25	07/01/25	
Q2444-11	1ST-PL-RESTROOM-3-MENS-SINK-1	Water			06/27/25			06/27/25
			Metals Group4	200.7		06/30/25	07/01/25	
Q2444-12	1ST-PL-RESTROOM-3-MENS-SINK-2	Water			06/27/25			06/27/25
			Metals Group4	200.7		06/30/25	07/01/25	