



Atlas Environmental Lab, Corp
255 West 36th Street, Suite# 1503
New York, NY 10018
Phone: (212) 563-0400 Fax: (212) 563-0401
www.atlasenvironmentallab.com

Report of Bacteriological Examination (Heterotrophic Plate Count)

Client: Alliance Technical Group

Collected/Submitted by: Client

Project Name/No.: NYU Clinical Lab Water Testing 2025-H25224389 / Q2456

Project Address:

Matrix: Water

Lab ID: HP0625051

Date Received: 6/27/2025

Time Received: 14:20

Report Date: 6/29/2025

Sample ID#	Sample Collected	Location/Description	Incubation in/out	HPC (cfu/ml)
Client ID#	Date/Time		Date/Time	
01	06/27/2025 @ 11:30	TH-401A-SINK-1	Incubated in: 06/27/2025 @ 14:51	<1
HP0625051-1			Incubated out: 06/29/2025 @ 14:51	
02	06/27/2025 @ 11:30	TH-401A-SINK-2	Incubated in: 06/27/2025 @ 14:51	<1
HP0625051-2			Incubated out: 06/29/2025 @ 14:51	
03	06/27/2025 @ 12:00	CC-10TH-FL	Incubated in: 06/27/2025 @ 14:51	<1
HP0625051-3			Incubated out: 06/29/2025 @ 14:51	
04	06/27/2025 @ 12:15	CC-3RD-FL	Incubated in: 06/27/2025 @ 14:51	1
HP0625051-4			Incubated out: 06/29/2025 @ 14:51	
05	06/27/2025 @ 12:15	7N-SKIRBALL	Incubated in: 06/27/2025 @ 14:51	5
HP0625051-5			Incubated out: 06/29/2025 @ 14:51	
06	06/27/2025 @ 12:15	TH-430-DI-1	Incubated in: 06/27/2025 @ 14:51	1
HP0625051-6			Incubated out: 06/29/2025 @ 14:51	



Atlas Environmental Lab, Corp
255 West 36th Street, Suite# 1503
New York, NY 10018
Phone: (212) 563-0400 Fax: (212) 563-0401
www.atlasenvironmentallab.com

Report of Bacteriological Examination (Heterotrophic Plate Count)

Client: Alliance Technical Group

Collected/Submitted by: Client

Project Name/No.: NYU Clinical Lab Water Testing 2025-H25224389 / Q2456

Project Address:

Matrix: Water

Lab ID: HP0625051

Date Received: 6/27/2025

Time Received: 14:20

Report Date: 6/29/2025

Sample ID#	Sample Collected	Location/Description	Incubation in/out	HPC (cfu/ml)
Client ID#	Date/Time		Date/Time	
07	06/27/2025 @ 12:15	TH-430-DI-2	Incubated in: 06/27/2025 @ 14:51	90
HP0625051-7			Incubated out: 06/29/2025 @ 14:51	
08	06/27/2025 @ 12:15	TH-430-DI-3	Incubated in: 06/27/2025 @ 14:51	38
HP0625051-8			Incubated out: 06/29/2025 @ 14:51	
09	06/27/2025 @ 12:15	TH-430-DI-4	Incubated in: 06/27/2025 @ 14:51	<1
HP0625051-9			Incubated out: 06/29/2025 @ 14:51	

HS

Method: Potable: SM 20, 21-23 9215 B (-04); Non Potable: SM 18-21 9215 B

ELAP Method 9136

Analyst: MN

Approved by: 

This laboratory report may not be reproduced, except in full, without the written approval of Atlas Environmental Lab corp.

Results relate only to the items tested.

NYS-ELAP#11999