

Hit Summary Sheet
SW-846

SDG No.: Q2520

Order ID: Q2520

Client: Safety Environmental Co. of NY, Inc.

Project ID: Childrens Harbor Montessori School

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
Client ID : A-3								
Q2520-03	A-3	Water	Lead	1.63	J	1.21	6.00	ug/L
Client ID : A-4								
Q2520-04	A-4	Water	Lead	1.21	J	1.21	6.00	ug/L
Client ID : A-5								
Q2520-05	A-5	Water	Lead	1.86	J	1.21	6.00	ug/L
Client ID : A-7								
Q2520-07	A-7	Water	Lead	2.00	J	1.21	6.00	ug/L
Client ID : A-8								
Q2520-08	A-8	Water	Lead	1.22	J	1.21	6.00	ug/L
Client ID : A-12								
Q2520-12	A-12	Water	Lead	1.62	J	1.21	6.00	ug/L
Client ID : A-13								
Q2520-13	A-13	Water	Lead	1.23	J	1.21	6.00	ug/L
Client ID : A-17								
Q2520-17	A-17	Water	Lead	2.02	J	1.21	6.00	ug/L
Client ID : A-18								
Q2520-18	A-18	Water	Lead	1.31	J	1.21	6.00	ug/L
Client ID : A-19								
Q2520-19	A-19	Water	Lead	1.69	J	1.21	6.00	ug/L
Client ID : A-20								
Q2520-20	A-20	Water	Lead	1.31	J	1.21	6.00	ug/L
Client ID : A-21								
Q2520-21	A-21	Water	Lead	1.44	J	1.21	6.00	ug/L
Client ID : A-23								
Q2520-23	A-23	Water	Lead	2.13	J	1.21	6.00	ug/L
Client ID : A-24								
Q2520-24	A-24	Water	Lead	1.53	J	1.21	6.00	ug/L

A

B

C

D



SAMPLE DATA

A

B

C

D

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-1	SDG No.:	Q2520
Lab Sample ID:	Q2520-01	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	07/09/25 10:25	07/11/25 03:56	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-2	SDG No.:	Q2520
Lab Sample ID:	Q2520-02	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	07/09/25 10:25	07/11/25 04:01	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-3	SDG No.:	Q2520
Lab Sample ID:	Q2520-03	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.63	J	1	1.21	6.00	ug/L	07/09/25 10:25	07/11/25 04:05	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-4	SDG No.:	Q2520
Lab Sample ID:	Q2520-04	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	J	1	1.21	6.00	ug/L	07/09/25 10:25	07/15/25 22:30	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-5	SDG No.:	Q2520
Lab Sample ID:	Q2520-05	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.86	J	1	1.21	6.00	ug/L	07/09/25 10:25	07/11/25 04:31	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-6	SDG No.:	Q2520
Lab Sample ID:	Q2520-06	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	07/09/25 10:25	07/15/25 22:25	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-7	SDG No.:	Q2520
Lab Sample ID:	Q2520-07	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	2.00	J	1	1.21	6.00	ug/L	07/09/25 10:25	07/11/25 04:40	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-8	SDG No.:	Q2520
Lab Sample ID:	Q2520-08	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.22	J	1	1.21	6.00	ug/L	07/09/25 10:25	07/11/25 04:44	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-9	SDG No.:	Q2520
Lab Sample ID:	Q2520-09	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	07/09/25 10:25	07/11/25 04:49	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-10	SDG No.:	Q2520
Lab Sample ID:	Q2520-10	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	07/09/25 10:25	07/11/25 04:53	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-11	SDG No.:	Q2520
Lab Sample ID:	Q2520-11	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	07/09/25 10:25	07/11/25 04:58	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-12	SDG No.:	Q2520
Lab Sample ID:	Q2520-12	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.62	J	1	1.21	6.00	ug/L	07/09/25 10:25	07/11/25 05:02	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-13	SDG No.:	Q2520
Lab Sample ID:	Q2520-13	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.23	J	1	1.21	6.00	ug/L	07/09/25 10:25	07/11/25 05:06	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-14	SDG No.:	Q2520
Lab Sample ID:	Q2520-14	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	07/09/25 10:25	07/11/25 05:11	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-15	SDG No.:	Q2520
Lab Sample ID:	Q2520-15	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	07/09/25 10:25	07/11/25 05:33	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-16	SDG No.:	Q2520
Lab Sample ID:	Q2520-16	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	07/09/25 10:25	07/11/25 05:37	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-17	SDG No.:	Q2520
Lab Sample ID:	Q2520-17	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	2.02	J	1	1.21	6.00	ug/L	07/09/25 10:25	07/11/25 05:41	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-18	SDG No.:	Q2520
Lab Sample ID:	Q2520-18	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.31	J	1	1.21	6.00	ug/L	07/09/25 10:25	07/11/25 05:46	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-19	SDG No.:	Q2520
Lab Sample ID:	Q2520-19	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.69	J	1	1.21	6.00	ug/L	07/09/25 10:25	07/11/25 05:50	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-20	SDG No.:	Q2520
Lab Sample ID:	Q2520-20	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.31	J	1	1.21	6.00	ug/L	07/09/25 10:25	07/11/25 05:55	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-21	SDG No.:	Q2520
Lab Sample ID:	Q2520-21	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.44	J	1	1.21	6.00	ug/L	07/09/25 10:16	07/11/25 03:34	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-22	SDG No.:	Q2520
Lab Sample ID:	Q2520-22	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	07/09/25 10:16	07/11/25 03:39	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-23	SDG No.:	Q2520
Lab Sample ID:	Q2520-23	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	2.13	J	1	1.21	6.00	ug/L	07/09/25 10:16	07/11/25 03:43	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	06/26/25
Project:	Childrens Harbor Montessori School	Date Received:	07/08/25
Client Sample ID:	A-24	SDG No.:	Q2520
Lab Sample ID:	Q2520-24	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.53	J	1	1.21	6.00	ug/L	07/09/25 10:16	07/10/25 20:26	EPA 200.7	E200.7

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

LAB CHRONICLE

OrderID:	Q2520	OrderDate:	7/8/2025 11:18:03 AM
Client:	Safety Environmental Co. of NY, Inc.	Project:	Childrens Harbor Montessori School
Contact:	Francis Owoh	Location:	O23

LabID	ClientID	Matrix	Test	Method	Sample Date	Prep Date	Anal Date	Received
Q2520-01	A-1	Water	Metals Group3	200.7	06/26/25	07/09/25	07/11/25	07/08/25
Q2520-02	A-2	Water	Metals Group3	200.7	06/26/25	07/09/25	07/11/25	07/08/25
Q2520-03	A-3	Water	Metals Group3	200.7	06/26/25	07/09/25	07/11/25	07/08/25
Q2520-04	A-4	Water	Metals Group3	200.7	06/26/25	07/09/25	07/15/25	07/08/25
Q2520-05	A-5	Water	Metals Group3	200.7	06/26/25	07/09/25	07/11/25	07/08/25
Q2520-06	A-6	Water	Metals Group3	200.7	06/26/25	07/09/25	07/15/25	07/08/25
Q2520-07	A-7	Water	Metals Group3	200.7	06/26/25	07/09/25	07/11/25	07/08/25
Q2520-08	A-8	Water	Metals Group3	200.7	06/26/25	07/09/25	07/11/25	07/08/25
Q2520-09	A-9	Water	Metals Group3	200.7	06/26/25	07/09/25	07/11/25	07/08/25
Q2520-10	A-10	Water	Metals Group3	200.7	06/26/25	07/09/25	07/11/25	07/08/25
Q2520-11	A-11	Water	Metals Group3	200.7	06/26/25	07/09/25	07/11/25	07/08/25
Q2520-12	A-12	Water			06/26/25			07/08/25

LAB CHRONICLE

			Metals Group3	200.7		07/09/25	07/11/25	
Q2520-13	A-13	Water			06/26/25			07/08/25
			Metals Group3	200.7		07/09/25	07/11/25	
Q2520-14	A-14	Water			06/26/25			07/08/25
			Metals Group3	200.7		07/09/25	07/11/25	
Q2520-15	A-15	Water			06/26/25			07/08/25
			Metals Group3	200.7		07/09/25	07/11/25	
Q2520-16	A-16	Water			06/26/25			07/08/25
			Metals Group3	200.7		07/09/25	07/11/25	
Q2520-17	A-17	Water			06/26/25			07/08/25
			Metals Group3	200.7		07/09/25	07/11/25	
Q2520-18	A-18	Water			06/26/25			07/08/25
			Metals Group3	200.7		07/09/25	07/11/25	
Q2520-19	A-19	Water			06/26/25			07/08/25
			Metals Group3	200.7		07/09/25	07/11/25	
Q2520-20	A-20	Water			06/26/25			07/08/25
			Metals Group3	200.7		07/09/25	07/11/25	
Q2520-21	A-21	Water			06/26/25			07/08/25
			Metals Group3	200.7		07/09/25	07/11/25	
Q2520-22	A-22	Water			06/26/25			07/08/25
			Metals Group3	200.7		07/09/25	07/11/25	
Q2520-23	A-23	Water			06/26/25			07/08/25
			Metals Group3	200.7		07/09/25	07/11/25	
Q2520-24	A-24	Water			06/26/25			07/08/25
			Metals Group3	200.7		07/09/25	07/10/25	