

Report of Analysis

Client:	Parkway Generation Operating LLC	Date Collected:	07/15/25
Project:	Linden Generating Station - 402	Date Received:	07/15/25
Client Sample ID:	402	SDG No.:	Q2606
Lab Sample ID:	Q2606-01	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7440-50-8	Copper	10.0	U	1	1.89	10.0	ug/L	07/16/25 10:15	07/17/25 14:32	EPA 200.7	
7439-97-6	Mercury	0.20	U	1	0.027	0.20	ug/L	07/21/25 09:00	07/21/25 15:32	E245.1	
7440-02-0	Nickel	6.37	J	1	1.90	20.0	ug/L	07/16/25 10:15	07/17/25 14:32	EPA 200.7	
7440-28-0	Thallium	20.0	U	1	2.51	20.0	ug/L	07/16/25 10:15	07/17/25 14:32	EPA 200.7	
7440-66-6	Zinc	33.0		1	2.00	20.0	ug/L	07/16/25 10:15	07/17/25 14:32	EPA 200.7	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Mercury			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N = Spiked sample recovery not within control limits