

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q2682
Project:	Linden Generating Station - Towers	Sample ID:	Q2682-02
Client ID:	TOWER-2DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TSS	mg/L	+/-5	2.30	J	2.30	J	1	0		07/25/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q2682
Project:	Linden Generating Station - Towers	Sample ID:	Q2683-08
Client ID:	DSN003DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TDS	mg/L	+/-5	1580		1630		1	3.3		07/24/2025