

Laboratory Control Sample Summary

Client: Parkway Generation Operating LLC

SDG No.: Q2682

Project: Linden Generating Station - Towers

Run No.: LB136600

Analyte	Units	True Value	Result	Conc. Qualifier	% Recovery	Dilution Factor	Acceptance Limit %R	Analysis Date
Sample ID	LB136600BS							
TDS	mg/L	100	95.0		95	1	90-110	07/24/2025

Laboratory Control Sample Summary

Client: Parkway Generation Operating LLC

SDG No.: Q2682

Project: Linden Generating Station - Towers

Run No.: LB136626

Analyte	Units	True Value	Result	Conc. Qualifier	% Recovery	Dilution Factor	Acceptance Limit %R	Analysis Date
Sample ID	LB136626BS							
TSS	mg/L	550	532		97	1	90-110	07/25/2025