

## Report of Analysis

|                   |                                  |                 |                |
|-------------------|----------------------------------|-----------------|----------------|
| Client:           | Parkway Generation Operating LLC | Date Collected: | 07/23/25 09:48 |
| Project:          | Linden Generating Station - LRSA | Date Received:  | 07/23/25       |
| Client Sample ID: | DSN001                           | SDG No.:        | Q2683          |
| Lab Sample ID:    | Q2683-03                         | Matrix:         | WATER          |
|                   |                                  | % Solid:        | 0              |

| Parameter    | Conc. | Qua. | DF | MDL   | LOQ / CRQL | Units | Prep Date      | Date Ana.      | Ana Met.                   |
|--------------|-------|------|----|-------|------------|-------|----------------|----------------|----------------------------|
| Ammonia as N | 0.15  |      | 1  | 0.030 | 0.10       | mg/L  | 07/25/25 10:45 | 07/25/25 13:09 | SM 4500-NH3<br>B plus G-21 |
| BOD5         | 3.60  |      | 1  | 0.20  | 2.00       | mg/L  |                | 07/24/25 16:30 | SM 5210 B-16               |
| COD          | 76.4  |      | 1  | 1.50  | 10.0       | mg/L  |                | 07/25/25 12:49 | SM 5220 D-11               |
| TSS          | 14.0  |      | 1  | 1.00  | 4.00       | mg/L  |                | 07/25/25 16:00 | SM 2540 D-20               |

Comments: \_\_\_\_\_

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits