

Report of Analysis

Client:	Parkway Generation Operating LLC	Date Collected:	07/23/25 10:40
Project:	Linden Generating Station - LRSA	Date Received:	07/23/25
Client Sample ID:	DSN003	SDG No.:	Q2683
Lab Sample ID:	Q2683-07	Matrix:	WATER
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Ammonia as N	0.29		1	0.030	0.10	mg/L	07/25/25 10:45	07/25/25 13:09	SM 4500-NH3 B plus G-21
BOD5	2.82		1	0.20	2.00	mg/L		07/24/25 16:30	SM 5210 B-16
COD	18.5		1	1.50	10.0	mg/L		07/25/25 12:50	SM 5220 D-11
TSS	1.70	J	1	1.00	4.00	mg/L		07/25/25 16:00	SM 2540 D-20

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits