

## Matrix Spike Summary

<b>Client:</b>	Parkway Generation Operating LLC	<b>SDG No.:</b>	Q2683
<b>Project:</b>	Linden Generating Station - LRSA	<b>Sample ID:</b>	Q2683-01
<b>Client ID:</b>	DSN002MS	<b>Percent Solids for Spike Sample:</b>	0

Analyte	Units	Acceptance Limit %R	Spiked Result	Conc. Qualifier	Sample Result	Conc. Qualifier	Spike Added	Dilution Factor	% Rec	Qual	Analysis Date
Ammonia as N	mg/L	75-125	1.60		0.56		1	1	104		07/25/2025
COD	mg/L	75-125	85.5		28.6		50.0	1	114		07/25/2025

## Matrix Spike Summary

<b>Client:</b>	Parkway Generation Operating LLC	<b>SDG No.:</b>	Q2683
<b>Project:</b>	Linden Generating Station - LRSA	<b>Sample ID:</b>	Q2683-01
<b>Client ID:</b>	DSN002MSD	<b>Percent Solids for Spike Sample:</b>	0

Analyte	Units	Acceptance Limit %R	Spiked Result	Conc. Qualifier	Sample Result	Conc. Qualifier	Spike Added	Dilution Factor	% Rec	Qual	Analysis Date
Ammonia as N	mg/L	75-125	1.50		0.56		1	1	94		07/25/2025
COD	mg/L	75-125	86.5		28.6		50.0	1	116		07/25/2025