

Laboratory Control Sample Summary

Client: Tully Environmental, Inc

SDG No.: Q2699

Project: Transfer Station-SPDES

Run No.: LB136626

Analyte	Units	True Value	Result	Conc. Qualifier	% Recovery	Dilution Factor	Acceptance Limit %R	Analysis Date
Sample ID	LB136626BS							
TSS	mg/L	550	532		97	1	90-110	07/25/2025