

Preparation Blank Summary

Client: Scientific Design

SDG No.: Q2835

Project: Central Wastewater Treatment Facility 2025

Analyte	Units	Result	Acceptance Limits	Conc Qual	MDL	RDL	Analysis Date
Sample ID: BOD5	LB136821BL mg/L	< 0.2000	0.2000	U	0.20	2.0	08/14/2025
Sample ID: COD	LB136825BL mg/L	< 5.0000	5.0000	U	1.5	10.0	08/15/2025
Sample ID: TSS	LB136829BL mg/L	1	2.0000	J	1	4	08/15/2025