

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q2860
Project:	Linden Generating Station - Towers	Sample ID:	Q2835-02
Client ID:	Pilot PlantDUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TSS	mg/L	+/-5	1.00	U	1.00	U	1	0		08/15/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q2860
Project:	Linden Generating Station - Towers	Sample ID:	Q2842-03
Client ID:	MW-17B-55.5-081225DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TDS	mg/L	+/-5	197		196		1	0.51		08/14/2025