

Hit Summary Sheet
SW-846

SDG No.: Q2901

Order ID: Q2901

Client: ATC Group Services LLC

Project ID: Hazmat survey-Bellevue hospital CPE

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
Client ID :	HVAC DUCT SEALANT							
Q2901-01	HVAC DUCT SEALA SOIL	Aroclor-1254		3300	E	22.7	120	ug/kg
Total Concentration:				3,300.000				
Client ID :	HVAC DUCT SEALANTDL							
Q2901-01DL	HVAC DUCT SEALA SOIL	Aroclor-1254		2900	D	113	600	ug/kg
Total Concentration:				2,900.000				
Client ID :	EXTERIOR WINDOW CAULK							
Q2901-02	EXTERIOR WINDO SOIL	Aroclor-1260		17000	E	143	750	ug/kg
Total Concentration:				17,000.000				
Client ID :	EXTERIOR WINDOW CAULKE							
Q2901-02DL	EXTERIOR WINDO SOIL	Aroclor-1260		16000	D	713	3800	ug/kg
Total Concentration:				16,000.000				