

Duplicate Sample Summary

Client: Parkway Generation Operating LLC	SDG No.: Q2967
Project: Linden Generating Station - 402	Sample ID: Q2950-01
Client ID: 402DUP	Percent Solids for Spike Sample: 0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/AD	Qual	Analysis Date
Cyanide	mg/L	+/-20	0.0015	J	0.0013	J	1	14		08/28/2025
Free Cyanide	mg/L	+/-20	0.00096	U	0.00096	U	1	0		08/29/2025

Duplicate Sample Summary

Client: Parkway Generation Operating LLC	SDG No.: Q2967
Project: Linden Generating Station - 402	Sample ID: Q2950-01
Client ID: 402MSD	Percent Solids for Spike Sample: 0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Cyanide	mg/L	+/-20	0.034		0.034		1	0		08/28/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q2967
Project:	Linden Generating Station - 402	Sample ID:	Q2967-01
Client ID:	402DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Hexavalent Chromium	mg/L	+/-20	0.0030	U	0.0030	U	1	0		08/27/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q2967
Project:	Linden Generating Station - 402	Sample ID:	Q2967-01
Client ID:	402MSD	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Hexavalent Chromium	mg/L	+/-20	0.98		0.99		2	0.61		08/27/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q2967
Project:	Linden Generating Station - 402	Sample ID:	Q2971-37
Client ID:	GROUNDWATERDUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/AD	Qual	Analysis Date
Ammonia as N	mg/L	+/-20	0.030	U	0.030	U	1	0		08/29/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q2967
Project:	Linden Generating Station - 402	Sample ID:	Q2971-37
Client ID:	GROUNDWATERMSD	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Ammonia as N	mg/L	+/-20	1.10		1.00		1	10		08/29/2025