

Duplicate Sample Summary

Client: Parkway Generation Operating LLC	SDG No.: Q3010
Project: Linden Generating Station - 402	Sample ID: LB137082BS
Client ID: LB137082BSD	Percent Solids for Spike Sample: 0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TPH	mg/L	+/-18	17.0		17.2		1	1.17		09/05/2025

Duplicate Sample Summary

Client: Parkway Generation Operating LLC Project: Linden Generating Station - 402 Client ID: 402DUP	SDG No.: Q3010 Sample ID: Q3010-01 Percent Solids for Spike Sample: 0
--	--

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Field pH	pH	+/-20	6.91		6.92		1	0.14		09/03/2025