

Hit Summary Sheet
SW-846

SDG No.: Q3014

Order ID: Q3014

Client: ATC Group Services LLC

Project ID: Hazmat survey-Bellevue hospital CPE

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
Client ID : Red Firestop Sealant								
Q3014-01	Red Firestop Sealant	SOIL	Aroclor-1254	1600		26.8	142	ug/kg
Q3014-01	Red Firestop Sealant	SOIL	Aroclor-1260	955		26.9	142	ug/kg
Total Concentration:				2,600.000				
Client ID : Sidewalk Joint Caulk								
Q3014-02	Sidewalk Joint Caulk	SOIL	Aroclor-1254	314		53.5	283	ug/kg
Q3014-02	Sidewalk Joint Caulk	SOIL	Aroclor-1260	230	J	53.8	283	ug/kg
Total Concentration:				544.000				
Client ID : Ext Metal Wall panel Caulk								
Q3014-03	Ext Metal Wall panel C	SOIL	Aroclor-1254	267	J	59.1	313	ug/kg
Q3014-03	Ext Metal Wall panel(SOIL	Aroclor-1260	206	J	59.4	313	ug/kg
Total Concentration:				472.000				



SAMPLE DATA

A

B

C

D

Report of Analysis

Client:	ATC Group Services LLC		Date Collected:	09/03/25	
Project:	Hazmat survey-Bellevue hospital CPEP		Date Received:	09/04/25	
Client Sample ID:	Red Firestop Sealant		SDG No.:	Q3014	
Lab Sample ID:	Q3014-01		Matrix:	SOIL	
Analytical Method:	8082A		% Solid:	100	Decanted:
Sample Wt/Vol:	3.6	Units: g	Final Vol:	10000	uL
Soil Aliquot Vol:		uL	Test:	PCB Group1	
Extraction Type:			Injection Volume :		
GPC Factor :	1.0	PH :			
Prep Method :	SW3541B				

File ID/Qc Batch:	Dilution:	Prep Date	Date Analyzed	Prep Batch ID
PO113765.D	1	09/16/25 10:35	09/16/25 15:41	PB169705

CAS Number	Parameter	Conc.	Qualifier	MDL	LOQ / CRQL	Units(Dry Weight)
TARGETS						
12674-11-2	Aroclor-1016	32.9	U	32.9	142	ug/kg
11104-28-2	Aroclor-1221	33.6	U	33.6	142	ug/kg
11141-16-5	Aroclor-1232	31.0	U	31.0	142	ug/kg
53469-21-9	Aroclor-1242	33.4	U	33.4	142	ug/kg
12672-29-6	Aroclor-1248	49.3	U	49.3	142	ug/kg
11097-69-1	Aroclor-1254	1600		26.8	142	ug/kg
37324-23-5	Aroclor-1262	41.8	U	41.8	142	ug/kg
11100-14-4	Aroclor-1268	30.0	U	30.0	142	ug/kg
11096-82-5	Aroclor-1260	955		26.9	142	ug/kg
Total PCBs	Total PCBs	2600		53.7	142	ug/kg
SURROGATES						
877-09-8	Tetrachloro-m-xylene	18.6		32 - 144	93%	SPK: 20
2051-24-3	Decachlorobiphenyl	18.6		32 - 175	93%	SPK: 20

Comments:

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

E = Value Exceeds Calibration Range

P = Indicates >25% difference for detected concentrations between the two GC columns

Q = indicates LCS control criteria did not meet requirements

M = MS/MSD acceptance criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

N = Presumptive Evidence of a Compound

* = Values outside of QC limits

D = Dilution

S = Indicates estimated value where valid five-point calibration was not performed prior to analyte detection in sample.

() = Laboratory InHouse Limit

Report of Analysis

Client:	ATC Group Services LLC		Date Collected:	09/03/25	
Project:	Hazmat survey-Bellevue hospital CPEP		Date Received:	09/04/25	
Client Sample ID:	Sidewalk Joint Caulk		SDG No.:	Q3014	
Lab Sample ID:	Q3014-02		Matrix:	SOIL	
Analytical Method:	8082A		% Solid:	100	Decanted:
Sample Wt/Vol:	1.8	Units: g	Final Vol:	10000	uL
Soil Aliquot Vol:		uL	Test:	PCB Group1	
Extraction Type:			Injection Volume :		
GPC Factor :	1.0	PH :			
Prep Method :	SW3541B				

File ID/Qc Batch:	Dilution:	Prep Date	Date Analyzed	Prep Batch ID
PO113763.D	1	09/16/25 10:35	09/16/25 15:05	PB169705

CAS Number	Parameter	Conc.	Qualifier	MDL	LOQ / CRQL	Units(Dry Weight)
TARGETS						
12674-11-2	Aroclor-1016	65.8	U	65.8	283	ug/kg
11104-28-2	Aroclor-1221	67.2	U	67.2	283	ug/kg
11141-16-5	Aroclor-1232	62.0	U	62.0	283	ug/kg
53469-21-9	Aroclor-1242	66.8	U	66.8	283	ug/kg
12672-29-6	Aroclor-1248	98.7	U	98.7	283	ug/kg
11097-69-1	Aroclor-1254	314		53.5	283	ug/kg
37324-23-5	Aroclor-1262	83.7	U	83.7	283	ug/kg
11100-14-4	Aroclor-1268	60.0	U	60.0	283	ug/kg
11096-82-5	Aroclor-1260	230	J	53.8	283	ug/kg
Total PCBs	Total PCBs	544		107	283	ug/kg
SURROGATES						
877-09-8	Tetrachloro-m-xylene	23.8		32 - 144	119%	SPK: 20
2051-24-3	Decachlorobiphenyl	19.1		32 - 175	95%	SPK: 20

Comments:

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

E = Value Exceeds Calibration Range

P = Indicates >25% difference for detected concentrations between the two GC columns

Q = indicates LCS control criteria did not meet requirements

M = MS/MSD acceptance criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

N = Presumptive Evidence of a Compound

* = Values outside of QC limits

D = Dilution

S = Indicates estimated value where valid five-point calibration was not performed prior to analyte detection in sample.

() = Laboratory InHouse Limit

Report of Analysis

Client:	ATC Group Services LLC		Date Collected:	09/03/25	
Project:	Hazmat survey-Bellevue hospital CPEP		Date Received:	09/04/25	
Client Sample ID:	Ext Metal Wall panel Caulk		SDG No.:	Q3014	
Lab Sample ID:	Q3014-03		Matrix:	SOIL	
Analytical Method:	8082A		% Solid:	100	Decanted:
Sample Wt/Vol:	1.63	Units: g	Final Vol:	10000	uL
Soil Aliquot Vol:		uL	Test:	PCB Group1	
Extraction Type:			Injection Volume :		
GPC Factor :	1.0	PH :			
Prep Method :	SW3541B				

File ID/Qc Batch:	Dilution:	Prep Date	Date Analyzed	Prep Batch ID
PO113764.D	1	09/16/25 10:35	09/16/25 15:22	PB169705

CAS Number	Parameter	Conc.	Qualifier	MDL	LOQ / CRQL	Units(Dry Weight)
TARGETS						
12674-11-2	Aroclor-1016	72.7	U	72.7	313	ug/kg
11104-28-2	Aroclor-1221	74.2	U	74.2	313	ug/kg
11141-16-5	Aroclor-1232	68.5	U	68.5	313	ug/kg
53469-21-9	Aroclor-1242	73.8	U	73.8	313	ug/kg
12672-29-6	Aroclor-1248	109	U	109	313	ug/kg
11097-69-1	Aroclor-1254	267	J	59.1	313	ug/kg
37324-23-5	Aroclor-1262	92.4	U	92.4	313	ug/kg
11100-14-4	Aroclor-1268	66.3	U	66.3	313	ug/kg
11096-82-5	Aroclor-1260	206	J	59.4	313	ug/kg
Total PCBs	Total PCBs	472		119	313	ug/kg
SURROGATES						
877-09-8	Tetrachloro-m-xylene	21.3		32 - 144	106%	SPK: 20
2051-24-3	Decachlorobiphenyl	18.9		32 - 175	94%	SPK: 20

Comments:

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

E = Value Exceeds Calibration Range

P = Indicates >25% difference for detected concentrations between the two GC columns

Q = indicates LCS control criteria did not meet requirements

M = MS/MSD acceptance criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

N = Presumptive Evidence of a Compound

* = Values outside of QC limits

D = Dilution

S = Indicates estimated value where valid five-point calibration was not performed prior to analyte detection in sample.

() = Laboratory InHouse Limit

LAB CHRONICLE

OrderID:	Q3014	OrderDate:	9/4/2025 10:02:00 AM
Client:	ATC Group Services LLC	Project:	Hazmat survey-Bellevue hospital CPEP
Contact:	Francis Pierre	Location:	J11

LabID	ClientID	Matrix	Test	Method	Sample Date	Prep Date	Anal Date	Received
Q3014-01	Red Firestop Sealant	SOIL	PCB Group1	8082A	09/03/25	09/16/25	09/16/25	09/04/25
Q3014-02	Sidewalk Joint Caulk	SOIL	PCB Group1	8082A	09/03/25	09/16/25	09/16/25	09/04/25
Q3014-03	Ext Metal Wall panel Caulk	SOIL	PCB Group1	8082A	09/03/25	09/16/25	09/16/25	09/04/25