

## Report of Analysis

Client:	ATC Group Services LLC		Date Collected:	09/03/25	
Project:	Hazmat survey-Bellevue hospital CPEP		Date Received:	09/04/25	
Client Sample ID:	Ext Metal Wall panel Caulk		SDG No.:	Q3014	
Lab Sample ID:	Q3014-03		Matrix:	SOIL	
Analytical Method:	8082A		% Solid:	100	Decanted:
Sample Wt/Vol:	1.63	Units: g	Final Vol:	10000	uL
Soil Aliquot Vol:		uL	Test:	PCB Group1	
Extraction Type:			Injection Volume :		
GPC Factor :	1.0	PH :			
Prep Method :	SW3541B				

File ID/Qc Batch:	Dilution:	Prep Date	Date Analyzed	Prep Batch ID
PO113764.D	1	09/16/25 10:35	09/16/25 15:22	PB169705

CAS Number	Parameter	Conc.	Qualifier	MDL	LOQ / CRQL	Units(Dry Weight)
<b>TARGETS</b>						
12674-11-2	Aroclor-1016	72.7	U	72.7	313	ug/kg
11104-28-2	Aroclor-1221	74.2	U	74.2	313	ug/kg
11141-16-5	Aroclor-1232	68.5	U	68.5	313	ug/kg
53469-21-9	Aroclor-1242	73.8	U	73.8	313	ug/kg
12672-29-6	Aroclor-1248	109	U	109	313	ug/kg
11097-69-1	Aroclor-1254	267	J	59.1	313	ug/kg
37324-23-5	Aroclor-1262	92.4	U	92.4	313	ug/kg
11100-14-4	Aroclor-1268	66.3	U	66.3	313	ug/kg
11096-82-5	Aroclor-1260	206	J	59.4	313	ug/kg
Total PCBs	Total PCBs	472		119	313	ug/kg
<b>SURROGATES</b>						
877-09-8	Tetrachloro-m-xylene	21.3		32 - 144	106%	SPK: 20
2051-24-3	Decachlorobiphenyl	18.9		32 - 175	94%	SPK: 20

### Comments:

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

E = Value Exceeds Calibration Range

P = Indicates >25% difference for detected concentrations between the two GC columns

Q = indicates LCS control criteria did not meet requirements

M = MS/MSD acceptance criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

N = Presumptive Evidence of a Compound

\* = Values outside of QC limits

D = Dilution

S = Indicates estimated value where valid five-point calibration was not performed prior to analyte detection in sample.

() = Laboratory InHouse Limit