

**Hit Summary Sheet**  
**SW-846**

**SDG No.:** Q3014

**Order ID:** Q3014

**Client:** ATC Group Services LLC

**Project ID:** Hazmat survey-Bellevue hospital CPE

| Sample ID                              | Client ID              | Matrix | Parameter    | Concentration | C | MDL  | RDL | Units |
|----------------------------------------|------------------------|--------|--------------|---------------|---|------|-----|-------|
| Client ID : Red Firestop Sealant       |                        |        |              |               |   |      |     |       |
| Q3014-01                               | Red Firestop Sealant   | SOIL   | Aroclor-1254 | 1600          |   | 26.8 | 142 | ug/kg |
| Q3014-01                               | Red Firestop Sealant   | SOIL   | Aroclor-1260 | 955           |   | 26.9 | 142 | ug/kg |
| Total Concentration:                   |                        |        |              | 2,600.000     |   |      |     |       |
| Client ID : Sidewalk Joint Caulk       |                        |        |              |               |   |      |     |       |
| Q3014-02                               | Sidewalk Joint Caulk   | SOIL   | Aroclor-1254 | 314           |   | 53.5 | 283 | ug/kg |
| Q3014-02                               | Sidewalk Joint Caulk   | SOIL   | Aroclor-1260 | 230           | J | 53.8 | 283 | ug/kg |
| Total Concentration:                   |                        |        |              | 544.000       |   |      |     |       |
| Client ID : Ext Metal Wall panel Caulk |                        |        |              |               |   |      |     |       |
| Q3014-03                               | Ext Metal Wall panel ( | SOIL   | Aroclor-1254 | 267           | J | 59.1 | 313 | ug/kg |
| Q3014-03                               | Ext Metal Wall panel(  | SOIL   | Aroclor-1260 | 206           | J | 59.4 | 313 | ug/kg |
| Total Concentration:                   |                        |        |              | 472.000       |   |      |     |       |