



A

B

C

# SAMPLE DATA

## Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	09/09/25 08:53
Project:	NYSOMH Emergency Service	Date Received:	09/09/25
Client Sample ID:	B2-W16-RM4080-SINK	SDG No.:	Q3061
Lab Sample ID:	Q3061-01	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.093	HJ	1	0.023	0.10	mg/L		09/10/25 11:27	SM 4500-Cl G-11
Turbidity	0.38	J	1	0.15	1.00	NTU		09/10/25 13:00	SM 2130 B-20

Comments: \_\_\_\_\_

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

## Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	09/09/25 09:07
Project:	NYSOMH Emergency Service	Date Received:	09/09/25
Client Sample ID:	B2-W16-RM4056-SINK	SDG No.:	Q3061
Lab Sample ID:	Q3061-02	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.052	HJ	1	0.023	0.10	mg/L		09/10/25 11:40	SM 4500-Cl G-11
Turbidity	0.56	J	1	0.15	1.00	NTU		09/10/25 13:07	SM 2130 B-20

Comments: \_\_\_\_\_

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

## Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	09/09/25 09:12
Project:	NYSOMH Emergency Service	Date Received:	09/09/25
Client Sample ID:	B2-W16-RM4057-RHSINK	SDG No.:	Q3061
Lab Sample ID:	Q3061-03	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.032	HJ	1	0.023	0.10	mg/L		09/10/25 11:43	SM 4500-Cl G-11
Turbidity	0.31	J	1	0.15	1.00	NTU		09/10/25 13:10	SM 2130 B-20

Comments: \_\_\_\_\_

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

## Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	09/09/25 09:15
Project:	NYSOMH Emergency Service	Date Received:	09/09/25
Client Sample ID:	B2-W16-LHDrinking Fountain	SDG No.:	Q3061
Lab Sample ID:	Q3061-04	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.073	HJ	1	0.023	0.10	mg/L		09/10/25 11:52	SM 4500-Cl G-11
Turbidity	1.76		1	0.15	1.00	NTU		09/10/25 13:14	SM 2130 B-20

Comments: \_\_\_\_\_

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

## Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	09/09/25 09:22
Project:	NYSOMH Emergency Service	Date Received:	09/09/25
Client Sample ID:	B2-W16-RM4065-Eyewash	SDG No.:	Q3061
Lab Sample ID:	Q3061-05	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.023	HU	1	0.023	0.10	mg/L		09/10/25 11:55	SM 4500-Cl G-11
Turbidity	0.40	J	1	0.15	1.00	NTU		09/10/25 13:20	SM 2130 B-20

Comments: \_\_\_\_\_

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

## Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	09/09/25 08:56
Project:	NYSOMH Emergency Service	Date Received:	09/09/25
Client Sample ID:	B2-W16-RM4088-SINK	SDG No.:	Q3061
Lab Sample ID:	Q3061-06	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.042	HJ	1	0.023	0.10	mg/L		09/10/25 11:58	SM 4500-Cl G-11
Turbidity	2.01		1	0.15	1.00	NTU		09/10/25 13:24	SM 2130 B-20

Comments:

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

## Report of Analysis

Client:	CHA Companies, Inc.	Date Collected:	09/09/25 09:02
Project:	NYSOMH Emergency Service	Date Received:	09/09/25
Client Sample ID:	B2-W16-RM4075-SINK	SDG No.:	Q3061
Lab Sample ID:	Q3061-07	Matrix:	Water
		% Solid:	0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.032	HJ	1	0.023	0.10	mg/L		09/10/25 12:01	SM 4500-Cl G-11
Turbidity	0.35	J	1	0.15	1.00	NTU		09/10/25 13:36	SM 2130 B-20

Comments: \_\_\_\_\_

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

## LAB CHRONICLE

<b>OrderID:</b>	Q3061	<b>OrderDate:</b>	9/9/2025 3:36:00 PM
<b>Client:</b>	CHA Companies, Inc.	<b>Project:</b>	NYSOMH Emergency Service
<b>Contact:</b>	Carrie Robinson	<b>Location:</b>	J12

LabID	ClientID	Matrix	Test	Method	Sample Date	Prep Date	Anal Date	Received
Q3061-01	B2-W16-RM4080-SIN K	Water	Residual Chlorine	SM4500 Cl G	09/09/25 08:53		09/10/25 11:27	09/09/25
			Turbidity	SM2130 B			09/10/25 13:00	
Q3061-02	B2-W16-RM4056-SIN K	Water	Residual Chlorine	SM4500 Cl G	09/09/25 09:07		09/10/25 11:40	09/09/25
			Turbidity	SM2130 B			09/10/25 13:07	
Q3061-03	B2-W16-RM4057-RHS INK	Water	Residual Chlorine	SM4500 Cl G	09/09/25 09:12		09/10/25 11:43	09/09/25
			Turbidity	SM2130 B			09/10/25 13:10	
Q3061-04	B2-W16-LHDrinking Fountain	Water	Residual Chlorine	SM4500 Cl G	09/09/25 09:15		09/10/25 11:52	09/09/25
			Turbidity	SM2130 B			09/10/25 13:14	
Q3061-05	B2-W16-RM4065-Eye wash	Water	Residual Chlorine	SM4500 Cl G	09/09/25 09:22		09/10/25 11:55	09/09/25

## LAB CHRONICLE

Q3061-06	B2-W16-RM4088-SIN K	Water	Turbidity	SM2130 B		09/10/25 13:20	09/09/25 08:56	09/09/25
			Residual Chlorine	SM4500 Cl G		09/10/25 11:58		
			Turbidity	SM2130 B		09/10/25 13:24		
Q3061-07	B2-W16-RM4075-SIN K	Water					09/09/25 09:02	09/09/25
			Residual Chlorine	SM4500 Cl G		09/10/25 12:01		
			Turbidity	SM2130 B		09/10/25 13:36		