

Duplicate Sample Summary

Client: CHA Companies, Inc.	SDG No.: Q3061
Project: NYSOMH Emergency Service	Sample ID: Q3061-01
Client ID: B2-W16-RM4080-SINKDUP	Percent Solids for Spike Sample: 0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/AD	Qual	Analysis Date
Residual Chlorine	mg/L	+/-20	0.093	J	0.093	J	1	0		09/10/2025
Turbidity	NTU	+/-20	0.38	J	0.38	J	1	1.31		09/10/2025

Duplicate Sample Summary

Client:	CHA Companies, Inc.	SDG No.:	Q3061
Project:	NYSOMH Emergency Service	Sample ID:	Q3061-01
Client ID:	B2-W16-RM4080-SINKMSD	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Residual Chlorine	mg/L	+/-20	0.44		0.43		1	2.3		09/10/2025