

Hit Summary Sheet
SW-846

SDG No.:	Q3144	Order ID:	Q3144
Client:	Safety Environmental Co. of NY, Inc.	Project ID:	Kids R First Pre School 2nd Floor Trenton

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
Client ID :	Mens Bathroom 1St Run							
Q3144-01	Mens Bathroom 1St Run	Water	Lead	7.04		1.21	6.00	ug/L
Client ID :	Men Bathroom 2nd Run							
Q3144-02	Men Bathroom 2nd Run	Water	Lead	2.50	J	1.21	6.00	ug/L
Client ID :	Classroom I 1St Run							
Q3144-03	Classroom I 1St Run	Water	Lead	21.3		1.21	6.00	ug/L
Client ID :	Classroom I 2nd Run							
Q3144-04	Classroom I 2nd Run	Water	Lead	3.89	J	1.21	6.00	ug/L
Client ID :	Ladies Bathroom 1St Run							
Q3144-05	Ladies Bathroom 1St Run	Water	Lead	2.15	J	1.21	6.00	ug/L
Client ID :	Ladies Bathroom 2nd Run							
Q3144-06	Ladies Bathroom 2nd Run	Water	Lead	1.99	J	1.21	6.00	ug/L
Client ID :	Fountain 1St Run							
Q3144-07	Fountain 1St Run	Water	Lead	2.62	J	1.21	6.00	ug/L
Client ID :	Fountain 2nd Run							
Q3144-08	Fountain 2nd Run	Water	Lead	1.48	J	1.21	6.00	ug/L
Client ID :	Classroom 4 1St Run							
Q3144-09	Classroom 4 1St Run	Water	Lead	3.63	J	1.21	6.00	ug/L
Client ID :	Classroom 4 2nd Run							
Q3144-10	Classroom 4 2nd Run	Water	Lead	2.06	J	1.21	6.00	ug/L
Client ID :	Classroom I Bathroom 1St Run							
Q3144-11	Classroom I Bathroom 1St Run	Water	Lead	1.21	J	1.21	6.00	ug/L
Client ID :	Classroom I Bathroom 2nd Run							
Q3144-12	Classroom I Bathroom 2nd Run	Water	Lead	1.44	J	1.21	6.00	ug/L
Client ID :	Classroom 2 Sink 1St Run							
Q3144-13	Classroom 2 Sink 1St Run	Water	Lead	2.33	J	1.21	6.00	ug/L
Client ID :	Classroom 2 Sink 2nd Run							
Q3144-14	Classroom 2 Sink 2nd Run	Water	Lead	2.65	J	1.21	6.00	ug/L
Client ID :	Classroom 2 Bathroom 2nd Run							

Hit Summary Sheet
SW-846

SDG No.: Q3144

Order ID: Q3144

Client: Safety Environmental Co. of NY, Inc.

Project ID: Kids R First Pre School 2nd Floor Trenton

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
Q3144-16	Classroom 2 Bathroom 2nd Run	Water	Lead	1.40	J	1.21	6.00	ug/L



SAMPLE DATA

A

B

C

D

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	09/18/25
Project:	Kids R First Pre School 2nd Floor Trenton	Date Received:	09/18/25
Client Sample ID:	Mens Bathroom 1St Run	SDG No.:	Q3144
Lab Sample ID:	Q3144-01	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	7.04	1	1.21		6.00	ug/L	09/22/25 12:35	09/22/25 14:21	EPA 200.7	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	09/18/25
Project:	Kids R First Pre School 2nd Floor Trenton	Date Received:	09/18/25
Client Sample ID:	Men Bathroom 2nd Run	SDG No.:	Q3144
Lab Sample ID:	Q3144-02	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	2.50	J	1	1.21	6.00	ug/L	09/22/25 12:35	09/22/25 14:25	EPA 200.7	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	09/18/25
Project:	Kids R First Pre School 2nd Floor Trenton	Date Received:	09/18/25
Client Sample ID:	Classroom I 1St Run	SDG No.:	Q3144
Lab Sample ID:	Q3144-03	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	21.3	1	1.21		6.00	ug/L	09/22/25 12:35	09/22/25 14:29	EPA 200.7	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	09/18/25
Project:	Kids R First Pre School 2nd Floor Trenton	Date Received:	09/18/25
Client Sample ID:	Classroom I 2nd Run	SDG No.:	Q3144
Lab Sample ID:	Q3144-04	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	3.89	J	1	1.21	6.00	ug/L	09/22/25 12:35	09/22/25 15:01	EPA 200.7	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	09/18/25
Project:	Kids R First Pre School 2nd Floor Trenton	Date Received:	09/18/25
Client Sample ID:	Ladies Bathroom 1St Run	SDG No.:	Q3144
Lab Sample ID:	Q3144-05	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	2.15	J	1	1.21	6.00	ug/L	09/22/25 12:35	09/22/25 15:05	EPA 200.7	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	09/18/25
Project:	Kids R First Pre School 2nd Floor Trenton	Date Received:	09/18/25
Client Sample ID:	Ladies Bathroom 2nd Run	SDG No.:	Q3144
Lab Sample ID:	Q3144-06	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.99	J	1	1.21	6.00	ug/L	09/22/25 12:35	09/22/25 15:09	EPA 200.7	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	09/18/25
Project:	Kids R First Pre School 2nd Floor Trenton	Date Received:	09/18/25
Client Sample ID:	Fountain 1St Run	SDG No.:	Q3144
Lab Sample ID:	Q3144-07	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	2.62	J	1	1.21	6.00	ug/L	09/22/25 12:35	09/22/25 15:14	EPA 200.7	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	09/18/25
Project:	Kids R First Pre School 2nd Floor Trenton	Date Received:	09/18/25
Client Sample ID:	Fountain 2nd Run	SDG No.:	Q3144
Lab Sample ID:	Q3144-08	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.48	J	1	1.21	6.00	ug/L	09/22/25 12:35	09/22/25 15:18	EPA 200.7	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	09/18/25
Project:	Kids R First Pre School 2nd Floor Trenton	Date Received:	09/18/25
Client Sample ID:	Classroom 4 1St Run	SDG No.:	Q3144
Lab Sample ID:	Q3144-09	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	3.63	J	1	1.21	6.00	ug/L	09/22/25 12:35	09/22/25 15:22	EPA 200.7	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	09/18/25
Project:	Kids R First Pre School 2nd Floor Trenton	Date Received:	09/18/25
Client Sample ID:	Classroom 4 2nd Run	SDG No.:	Q3144
Lab Sample ID:	Q3144-10	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	2.06	J	1	1.21	6.00	ug/L	09/22/25 12:35	09/22/25 15:26	EPA 200.7	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	09/18/25
Project:	Kids R First Pre School 2nd Floor Trenton	Date Received:	09/18/25
Client Sample ID:	Classroom I Bathroom 1St Run	SDG No.:	Q3144
Lab Sample ID:	Q3144-11	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	J	1	1.21	6.00	ug/L	09/22/25 12:35	09/22/25 15:30	EPA 200.7	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	09/18/25
Project:	Kids R First Pre School 2nd Floor Trenton	Date Received:	09/18/25
Client Sample ID:	Classroom I Bathroom 2nd Run	SDG No.:	Q3144
Lab Sample ID:	Q3144-12	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.44	J	1	1.21	6.00	ug/L	09/22/25 12:35	09/22/25 15:34	EPA 200.7	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	09/18/25
Project:	Kids R First Pre School 2nd Floor Trenton	Date Received:	09/18/25
Client Sample ID:	Classroom 2 Sink 1St Run	SDG No.:	Q3144
Lab Sample ID:	Q3144-13	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	2.33	J	1	1.21	6.00	ug/L	09/22/25 12:35	09/22/25 15:54	EPA 200.7	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	09/18/25
Project:	Kids R First Pre School 2nd Floor Trenton	Date Received:	09/18/25
Client Sample ID:	Classroom 2 Sink 2nd Run	SDG No.:	Q3144
Lab Sample ID:	Q3144-14	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	2.65	J	1	1.21	6.00	ug/L	09/22/25 12:35	09/22/25 15:58	EPA 200.7	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	09/18/25
Project:	Kids R First Pre School 2nd Floor Trenton	Date Received:	09/18/25
Client Sample ID:	Classroom 2 Bathroom 1St Run	SDG No.:	Q3144
Lab Sample ID:	Q3144-15	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.21	U	1	1.21	6.00	ug/L	09/22/25 12:35	09/22/25 16:02	EPA 200.7	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Safety Environmental Co. of NY, Inc.	Date Collected:	09/18/25
Project:	Kids R First Pre School 2nd Floor Trenton	Date Received:	09/18/25
Client Sample ID:	Classroom 2 Bathroom 2nd Run	SDG No.:	Q3144
Lab Sample ID:	Q3144-16	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.40	J	1	1.21	6.00	ug/L	09/22/25 12:35	09/22/25 16:06	EPA 200.7	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group3			

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

LAB CHRONICLE

OrderID:	Q3144	OrderDate:	9/19/2025 9:37:00 AM
Client:	Safety Environmental Co. of NY, Inc.	Project:	Kids R First Pre School 2nd Floor Trenton
Contact:	Francis Owoh	Location:	J22

LabID	ClientID	Matrix	Test	Method	Sample Date	Prep Date	Anal Date	Received
Q3144-01	Mens Bathroom 1St Run	Water			09/18/25			09/18/25
			Metals Group3	200.7		09/22/25	09/22/25	
Q3144-02	Men Bathroom 2nd Run	Water			09/18/25			09/18/25
			Metals Group3	200.7		09/22/25	09/22/25	
Q3144-03	Classroom I 1St Run	Water			09/18/25			09/18/25
			Metals Group3	200.7		09/22/25	09/22/25	
Q3144-04	Classroom I 2nd Run	Water			09/18/25			09/18/25
			Metals Group3	200.7		09/22/25	09/22/25	
Q3144-05	Ladies Bathroom 1St Run	Water			09/18/25			09/18/25
			Metals Group3	200.7		09/22/25	09/22/25	
Q3144-06	Ladies Bathroom 2nd Run	Water			09/18/25			09/18/25
			Metals Group3	200.7		09/22/25	09/22/25	
Q3144-07	Fountain 1St Run	Water			09/18/25			09/18/25
			Metals Group3	200.7		09/22/25	09/22/25	
Q3144-08	Fountain 2nd Run	Water			09/18/25			09/18/25
			Metals Group3	200.7		09/22/25	09/22/25	
Q3144-09	Classroom 4 1St Run	Water			09/18/25			09/18/25
			Metals Group3	200.7		09/22/25	09/22/25	
Q3144-10	Classroom 4 2nd Run	Water			09/18/25			09/18/25
			Metals Group3	200.7		09/22/25	09/22/25	

LAB CHRONICLE

Q3144-11	Classroom I Bathroom 1St Run	Water			09/18/25		09/18/25
			Metals Group3	200.7		09/22/25	09/22/25
Q3144-12	Classroom I Bathroom 2nd Run	Water			09/18/25		09/18/25
			Metals Group3	200.7		09/22/25	09/22/25
Q3144-13	Classroom 2 Sink 1St Run	Water			09/18/25		09/18/25
			Metals Group3	200.7		09/22/25	09/22/25
Q3144-14	Classroom 2 Sink 2nd Run	Water			09/18/25		09/18/25
			Metals Group3	200.7		09/22/25	09/22/25
Q3144-15	Classroom 2 Bathroom 1St Run	Water			09/18/25		09/18/25
			Metals Group3	200.7		09/22/25	09/22/25
Q3144-16	Classroom 2 Bathroom 2nd Run	Water			09/18/25		09/18/25
			Metals Group3	200.7		09/22/25	09/22/25