

Preparation Blank Summary

Client: Dal-Tile - Dickson Plant

SDG No.: Q3258

Project: Waste Water

Analyte	Units	Result	Acceptance Limits	Conc Qual	MDL	RDL	Analysis Date
Sample ID: LB137386BL Hexavalent Chromium	mg/L	< 0.0050	0.0050	U	0.003	0.01	10/01/2025
Sample ID: LB137388BL BOD5	mg/L	< 0.2000	0.2000	U	0.20	2.0	10/01/2025
Sample ID: LB137413BL Oil and Grease	mg/L	< 2.5000	2.5000	U	0.29	5.0	10/03/2025
Sample ID: LB137419BL TSS	mg/L	1	2.0000	J	1	4	10/03/2025
Sample ID: PB169946BL Ammonia as N	mg/L	< 0.0500	0.0500	U	0.03	0.1	10/03/2025
Sample ID: PB169962BL Cyanide	mg/L	< 0.0025	0.0025	U	0.0012	0.005	10/06/2025
Sample ID: PB170046BL Phosphorus, Total	mg/L	0.007	0.0250	J	0.005	0.05	10/09/2025
Sample ID: PB170085BL Cyanide	mg/L	< 0.0025	0.0025	U	0.0012	0.005	10/14/2025