



284 Sheffield Street, Mountainside, New Jersey 07092, Phone : 908 789 8900,  
Fax : 908 789 8922

**Hit Summary Sheet**  
**SW-846**

<b>SDG No.:</b>	Q3267	<b>Order ID:</b>	Q3267
<b>Client:</b>	METEM A GE POWER Business	<b>Project ID:</b>	Parsippany Wastewater Quarterly 2025

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
<b>Client ID : Q4</b>								
Q3267-01	Q4	Water	Chromium	453	D	26.5	250	ug/L
Q3267-01	Q4	Water	Nickel	2440	D	95.0	1000	ug/L
Q3267-01	Q4	Water	Zinc	196	JD	100	1000	ug/L



# SAMPLE DATA

A

B

C

D

## Report of Analysis

Client:	METEM A GE POWER Business	Date Collected:	10/01/25
Project:	Parsippany Wastewater Quarterly 2025	Date Received:	10/01/25
Client Sample ID:	Q4	SDG No.:	Q3267
Lab Sample ID:	Q3267-01	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7440-43-9	Cadmium	15.5	UD	50	15.5	150	ug/L	10/02/25 10:10	10/08/25 16:58	EPA 200.7	
7440-47-3	Chromium	453	D	50	26.5	250	ug/L	10/02/25 10:10	10/08/25 16:58	EPA 200.7	
7440-50-8	Copper	94.5	UD	50	94.5	500	ug/L	10/02/25 10:10	10/08/25 16:58	EPA 200.7	
7439-92-1	Lead	60.5	UD	50	60.5	300	ug/L	10/02/25 10:10	10/08/25 16:58	EPA 200.7	
7440-02-0	Nickel	2440	D	50	95.0	1000	ug/L	10/02/25 10:10	10/08/25 16:58	EPA 200.7	
7440-22-4	Silver	40.5	UD	50	40.5	250	ug/L	10/02/25 10:10	10/08/25 16:58	EPA 200.7	
7440-66-6	Zinc	196	JD	50	100	1000	ug/L	10/02/25 10:10	10/08/25 16:58	EPA 200.7	

Color Before:	Colorless	Clarity Before:	Clear	Texture:
Color After:	Colorless	Clarity After:	Clear	Artifacts:
Comments:	Metals Group5			

U = Not Detected  
 LOQ = Limit of Quantitation  
 MDL = Method Detection Limit  
 LOD = Limit of Detection  
 D = Dilution  
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value  
 B = Analyte Found in Associated Method Blank  
 \* = indicates the duplicate analysis is not within control limits.  
 E = Indicates the reported value is estimated because of the presence of interference.  
 OR = Over Range  
 N = Spiked sample recovery not within control limits

LAB CHRONICLE

OrderID:	Q3267	OrderDate:	10/1/2025 3:37:00 PM
Client:	METEM A GE POWER Business	Project:	Parsippany Wastewater Quarterly 2025
Contact:	Sundas Pervez	Location:	D31

LabID	ClientID	Matrix	Test	Method	Sample Date	Prep Date	Anal Date	Received
Q3267-01	Q4	Water	Metals Group5	200.7	10/01/25	10/02/25	10/08/25	10/01/25



A

B

C

# SAMPLE DATA

## Report of Analysis

Client: METEM A GE POWER Business  
Project: Parsippany Wastewater Quarterly 2025  
Client Sample ID: Q4  
Lab Sample ID: Q3267-01

Date Collected: 10/01/25 15:00  
Date Received: 10/01/25  
SDG No.: Q3267  
Matrix: WATER  
% Solid: 0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Cyanide	0.0012	U	1	0.0012	0.0050	mg/L	10/06/25 11:05	10/06/25 14:51	SM 4500-CN C-21 plus E-21
Field pH	7.64		1	0	0	pH		10/01/25 15:02	SM4500-H B

Comments: \_\_\_\_\_

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

LAB CHRONICLE

OrderID:	Q3267	OrderDate:	10/1/2025 3:37:00 PM
Client:	METEM A GE POWER Business	Project:	Parsippany Wastewater Quarterly 2025
Contact:	Sundas Pervez	Location:	D31

LabID	ClientID	Matrix	Test	Method	Sample Date	Prep Date	Anal Date	Received
Q3267-01	Q4	WATER			10/01/25 15:00			10/01/25
			Cyanide	SM4500-CN C,E		10/06/25	10/06/25 14:51	
			Field pH	SM4500-H B			10/01/25 15:02	