

Hit Summary Sheet
SW-846

SDG No.: Q3335 **Order ID:** Q3335
Client: Total Quality Environmental Inc. **Project ID:** Total Quality Environmental Inc

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
Client ID :	Basement Kitchen (1st draw)							
Q3335-01	Basement Kitchen (1st draw)	Water	Lead	92.4		1.15	6.00	ug/L
Client ID :	(2nd draw)							
Q3335-02	(2nd draw)	Water	Lead	3.31	J	1.15	6.00	ug/L
Client ID :	Adult Bathroom (1st draw)							
Q3335-03	Adult Bathroom (1st draw)	Water	Lead	96.9		1.15	6.00	ug/L
Client ID :	(2nd draw)							
Q3335-04	(2nd draw)	Water	Lead	1.94	J	1.15	6.00	ug/L
Client ID :	Drinking Fountain (1st draw)							
Q3335-05	Drinking Fountain (1st draw)	Water	Lead	29.5		1.15	6.00	ug/L
Client ID :	(2nd draw)							
Q3335-06	(2nd draw)	Water	Lead	3.74	J	1.15	6.00	ug/L
Client ID :	Kids Bathroom L (1st draw)							
Q3335-07	Kids Bathroom L (1st draw)	Water	Lead	164		1.15	6.00	ug/L
Client ID :	L (2nd draw)							
Q3335-08	L (2nd draw)	Water	Lead	23.8		1.15	6.00	ug/L
Client ID :	R (1st draw)							
Q3335-09	R (1st draw)	Water	Lead	106		1.15	6.00	ug/L
Client ID :	R (2nd draw)							
Q3335-10	R (2nd draw)	Water	Lead	3.07	J	1.15	6.00	ug/L
Client ID :	Main Hall L (1st draw)							
Q3335-11	Main Hall L (1st draw)	Water	Lead	21.5		1.15	6.00	ug/L
Client ID :	L (2nd draw)							
Q3335-12	L (2nd draw)	Water	Lead	6.15		1.15	6.00	ug/L
Client ID :	R (1st draw)							
Q3335-13	R (1st draw)	Water	Lead	10.0		1.15	6.00	ug/L
Client ID :	R (2nd draw)							
Q3335-14	R (2nd draw)	Water	Lead	35.1		1.15	6.00	ug/L



SAMPLE DATA

A

B

C

D

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	10/10/25
Project:	Total Quality Environmental Inc	Date Received:	10/13/25
Client Sample ID:	Basement Kitchen (1st draw)	SDG No.:	Q3335
Lab Sample ID:	Q3335-01	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	92.4		1	1.15	6.00	ug/L	10/14/25 10:50	10/17/25 16:03	6010D	SW3010

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

Report of Analysis

Client: Total Quality Environmental Inc.
Project: Total Quality Environmental Inc
Client Sample ID: (2nd draw)
Lab Sample ID: Q3335-02
Level (low/med): low

Date Collected: 10/10/25
Date Received: 10/13/25
SDG No.: Q3335
Matrix: Water
% Solid: 0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	3.31	J	1	1.15	6.00	ug/L	10/14/25 10:50	10/17/25 16:17	6010D	SW3010

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	10/10/25
Project:	Total Quality Environmental Inc	Date Received:	10/13/25
Client Sample ID:	Adult Bathroom (1st draw)	SDG No.:	Q3335
Lab Sample ID:	Q3335-03	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	96.9	1	1.15		6.00	ug/L	10/14/25 10:50	10/17/25 16:21	6010D	SW3010

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

Report of Analysis

Client: Total Quality Environmental Inc.
Project: Total Quality Environmental Inc
Client Sample ID: (2nd draw)
Lab Sample ID: Q3335-04
Level (low/med): low

Date Collected: 10/10/25
Date Received: 10/13/25
SDG No.: Q3335
Matrix: Water
% Solid: 0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.94	J	1	1.15	6.00	ug/L	10/14/25 10:50	10/17/25 16:25	6010D	SW3010

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	10/10/25
Project:	Total Quality Environmental Inc	Date Received:	10/13/25
Client Sample ID:	Drinking Fountain (1st draw)	SDG No.:	Q3335
Lab Sample ID:	Q3335-05	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	29.5	1	1.15		6.00	ug/L	10/14/25 10:50	10/17/25 16:30	6010D	SW3010

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	10/10/25
Project:	Total Quality Environmental Inc	Date Received:	10/13/25
Client Sample ID:	(2nd draw)	SDG No.:	Q3335
Lab Sample ID:	Q3335-06	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	3.74	J	1	1.15	6.00	ug/L	10/14/25 10:50	10/17/25 16:34	6010D	SW3010

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

Report of Analysis

Client: Total Quality Environmental Inc.
Project: Total Quality Environmental Inc
Client Sample ID: Kids Bathroom L (1st draw)
Lab Sample ID: Q3335-07
Level (low/med): low

Date Collected: 10/10/25
Date Received: 10/13/25
SDG No.: Q3335
Matrix: Water
% Solid: 0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	164	1	1.15		6.00	ug/L	10/14/25 10:50	10/17/25 16:38	6010D	SW3010

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

Report of Analysis

Client: Total Quality Environmental Inc.
Project: Total Quality Environmental Inc
Client Sample ID: L (2nd draw)
Lab Sample ID: Q3335-08
Level (low/med): low

Date Collected: 10/10/25
Date Received: 10/13/25
SDG No.: Q3335
Matrix: Water
% Solid: 0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	23.8		1	1.15	6.00	ug/L	10/14/25 10:50	10/17/25 16:42	6010D	SW3010

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

Report of Analysis

Client: Total Quality Environmental Inc.
Project: Total Quality Environmental Inc
Client Sample ID: R (1st draw)
Lab Sample ID: Q3335-09
Level (low/med): low

Date Collected: 10/10/25
Date Received: 10/13/25
SDG No.: Q3335
Matrix: Water
% Solid: 0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	106		1	1.15	6.00	ug/L	10/14/25 10:50	10/17/25 16:46	6010D	SW3010

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

Report of Analysis

Client: Total Quality Environmental Inc.
Project: Total Quality Environmental Inc
Client Sample ID: R (2nd draw)
Lab Sample ID: Q3335-10
Level (low/med): low

Date Collected: 10/10/25
Date Received: 10/13/25
SDG No.: Q3335
Matrix: Water
% Solid: 0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	3.07	J	1	1.15	6.00	ug/L	10/14/25 10:50	10/17/25 16:51	6010D	SW3010

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	10/10/25
Project:	Total Quality Environmental Inc	Date Received:	10/13/25
Client Sample ID:	Main Hall L (1st draw)	SDG No.:	Q3335
Lab Sample ID:	Q3335-11	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	21.5		1	1.15	6.00	ug/L	10/14/25 10:50	10/17/25 16:55	6010D	SW3010

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

Report of Analysis

Client: Total Quality Environmental Inc.
Project: Total Quality Environmental Inc
Client Sample ID: L (2nd draw)
Lab Sample ID: Q3335-12
Level (low/med): low

Date Collected: 10/10/25
Date Received: 10/13/25
SDG No.: Q3335
Matrix: Water
% Solid: 0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	6.15		1	1.15	6.00	ug/L	10/14/25 10:50	10/17/25 17:07	6010D	SW3010

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	10/10/25
Project:	Total Quality Environmental Inc	Date Received:	10/13/25
Client Sample ID:	R (1st draw)	SDG No.:	Q3335
Lab Sample ID:	Q3335-13	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	10.0	1	1.15		6.00	ug/L	10/14/25 10:50	10/17/25 17:12	6010D	SW3010

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	10/10/25
Project:	Total Quality Environmental Inc	Date Received:	10/13/25
Client Sample ID:	R (2nd draw)	SDG No.:	Q3335
Lab Sample ID:	Q3335-14	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	35.1		1	1.15	6.00	ug/L	10/14/25 10:50	10/17/25 17:16	6010D	SW3010

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

LAB CHRONICLE

OrderID:	Q3335	OrderDate:	10/13/2025 9:19:00 AM
Client:	Total Quality Environmental Inc.	Project:	Total Quality Environmental Inc
Contact:	Alex Rukasov	Location:	J52

LabID	ClientID	Matrix	Test	Method	Sample Date	Prep Date	Anal Date	Received
Q3335-01	Basement Kitchen (1st draw)	Water			10/10/25			10/13/25
			Metals Group3	6010D		10/14/25	10/17/25	
Q3335-02	(2nd draw)	Water			10/10/25			10/13/25
			Metals Group3	6010D		10/14/25	10/17/25	
Q3335-03	Adult Bathroom (1st draw)	Water			10/10/25			10/13/25
			Metals Group3	6010D		10/14/25	10/17/25	
Q3335-04	(2nd draw)	Water			10/10/25			10/13/25
			Metals Group3	6010D		10/14/25	10/17/25	
Q3335-05	Drinking Fountain (1st draw)	Water			10/10/25			10/13/25
			Metals Group3	6010D		10/14/25	10/17/25	
Q3335-06	(2nd draw)	Water			10/10/25			10/13/25
			Metals Group3	6010D		10/14/25	10/17/25	
Q3335-07	Kids Bathroom L (1st draw)	Water			10/10/25			10/13/25
			Metals Group3	6010D		10/14/25	10/17/25	
Q3335-08	L (2nd draw)	Water			10/10/25			10/13/25
			Metals Group3	6010D		10/14/25	10/17/25	
Q3335-09	R (1st draw)	Water			10/10/25			10/13/25
			Metals Group3	6010D		10/14/25	10/17/25	
Q3335-10	R (2nd draw)	Water			10/10/25			10/13/25
			Metals Group3	6010D		10/14/25	10/17/25	

LAB CHRONICLE

Q3335-11	Main Hall L (1st draw)	Water			10/10/25			10/13/25
			Metals Group3	6010D		10/14/25	10/17/25	
Q3335-12	L (2nd draw)	Water			10/10/25			10/13/25
			Metals Group3	6010D		10/14/25	10/17/25	
Q3335-13	R (1st draw)	Water			10/10/25			10/13/25
			Metals Group3	6010D		10/14/25	10/17/25	
Q3335-14	R (2nd draw)	Water			10/10/25			10/13/25
			Metals Group3	6010D		10/14/25	10/17/25	