

## Report of Analysis

|                   |                                  |                 |          |
|-------------------|----------------------------------|-----------------|----------|
| Client:           | Total Quality Environmental Inc. | Date Collected: | 10/10/25 |
| Project:          | Total Quality Environmental Inc  | Date Received:  | 10/13/25 |
| Client Sample ID: | Basement Kitchen (1st draw)      | SDG No.:        | Q3335    |
| Lab Sample ID:    | Q3335-01                         | Matrix:         | Water    |
| Level (low/med):  | low                              | % Solid:        | 0        |

| Cas       | Parameter | Conc. | Qua. | DF | MDL  | LOQ / CRQL | Units | Prep Date      | Date Ana.      | Ana Met. | Prep Met. |
|-----------|-----------|-------|------|----|------|------------|-------|----------------|----------------|----------|-----------|
| 7439-92-1 | Lead      | 92.4  |      | 1  | 1.15 | 6.00       | ug/L  | 10/14/25 10:50 | 10/17/25 16:03 | 6010D    | SW3010    |

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits