

Hit Summary Sheet
SW-846

SDG No.: Q3335

Order ID: Q3335

Client: Total Quality Environmental Inc.

Project ID: Total Quality Environmental Inc

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
Client ID :	Basement Kitchen (1st draw)							
Q3335-01	Basement Kitchen (1st draw)	Water	Lead	92.4		1.15	6.00	ug/L
Client ID :	(2nd draw)							
Q3335-02	(2nd draw)	Water	Lead	3.31	J	1.15	6.00	ug/L
Client ID :	Adult Bathroom (1st draw)							
Q3335-03	Adult Bathroom (1st draw)	Water	Lead	96.9		1.15	6.00	ug/L
Client ID :	(2nd draw)							
Q3335-04	(2nd draw)	Water	Lead	1.94	J	1.15	6.00	ug/L
Client ID :	Drinking Fountain (1st draw)							
Q3335-05	Drinking Fountain (1st draw)	Water	Lead	29.5		1.15	6.00	ug/L
Client ID :	(2nd draw)							
Q3335-06	(2nd draw)	Water	Lead	3.74	J	1.15	6.00	ug/L
Client ID :	Kids Bathroom L (1st draw)							
Q3335-07	Kids Bathroom L (1st draw)	Water	Lead	164		1.15	6.00	ug/L
Client ID :	L (2nd draw)							
Q3335-08	L (2nd draw)	Water	Lead	23.8		1.15	6.00	ug/L
Client ID :	R (1st draw)							
Q3335-09	R (1st draw)	Water	Lead	106		1.15	6.00	ug/L
Client ID :	R (2nd draw)							
Q3335-10	R (2nd draw)	Water	Lead	3.07	J	1.15	6.00	ug/L
Client ID :	Main Hall L (1st draw)							
Q3335-11	Main Hall L (1st draw)	Water	Lead	21.5		1.15	6.00	ug/L
Client ID :	L (2nd draw)							
Q3335-12	L (2nd draw)	Water	Lead	6.15		1.15	6.00	ug/L
Client ID :	R (1st draw)							
Q3335-13	R (1st draw)	Water	Lead	10.0		1.15	6.00	ug/L
Client ID :	R (2nd draw)							
Q3335-14	R (2nd draw)	Water	Lead	35.1		1.15	6.00	ug/L

Hit Summary Sheet
SW-846

SDG No.: Q3335

Order ID: Q3335

Client: Total Quality Environmental Inc.

Project ID: Total Quality Environmental Inc

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
-----------	-----------	--------	-----------	---------------	---	-----	-----	-------