
From: James Eagles
Sent: Wednesday, October 22, 2025 8:04 AM
To: Yazmeen Gomez
Cc: James Gunn; Mohammad Ahmed
Subject: Dal-Tile Dickson Facility October Samples

Good morning Yazmeen,

I took samples for the Dal-Tile Dickson yesterday, TN facility. During the site visit, their composite sampler once again did not pull enough wastewater to fill all of the composite sample bottles. I was able to fill the two bottles that did not have any preservatives in them as well as the 500ml bottles designated for Ammonia and Mercury testing.

When you receive the samples, you'll find the following bottles in the cooler:

- 3 x 1 Liter amber bottles with a grab samples for their Oil & Grease tests
- 1 x 500 ml bottle with a grab sample for their monthly cyanide test
- 2 x 500 ml bottles with the composite samples and no preservative (labeled Composite #1 and Composite #2)
 - Please use these for as many tests that can be conducted that they were asking for.
- 1 x 500 ml bottle with the composite sample for the mercury tests
- 1 x 500 ml bottle with the composite sample for the ammonia test

The details listed above are reflected on the CoC.

The cooler was designated for "Next Day Air" and the UPS tracking number is: **J4644862582**

Please let me know if you have any questions or need to discuss anything regarding this sampling event.

Thanks,

ENVIRONMENTAL³⁶⁰ now Alliance
TECHNICAL GROUP

James Eagles
Compliance Specialist
Mobile: 601-415-6913
www.alliancetg.com