



284 Sheffield Street, Mountainside, New Jersey 07092, Phone : 908 789 8900,
Fax : 908 789 8922

Hit Summary Sheet
SW-846

SDG No.: Q3420

Order ID: Q3420

Client: Dal-Tile

Project ID: Waste Water

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
Client ID : COMPOSITE								
Q3420-05	COMPOSITE	Water	Arsenic	51.5		2.56	10.0	ug/L
Q3420-05	COMPOSITE	Water	Chromium	15.9		1.06	5.00	ug/L
Q3420-05	COMPOSITE	Water	Copper	7.37	J	2.30	10.0	ug/L
Q3420-05	COMPOSITE	Water	Lead	1.84	J	1.15	6.00	ug/L
Q3420-05	COMPOSITE	Water	Mercury	1.86		0.076	0.20	ug/L
Q3420-05	COMPOSITE	Water	Nickel	15.0	J	1.53	20.0	ug/L
Q3420-05	COMPOSITE	Water	Selenium	492		4.82	10.0	ug/L
Q3420-05	COMPOSITE	Water	Zinc	266		8.33	20.0	ug/L