

Duplicate Sample Summary

Client: Parkway Generation Operating LLC	SDG No.: Q3448
Project: Linden Generating Station - LRSA	Sample ID: Q3420-05
Client ID: COMPOSITEDUP	Percent Solids for Spike Sample: 0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
BOD5	mg/L	+/-20	230		223		1	3.18		10/23/2025

Duplicate Sample Summary

Client: Parkway Generation Operating LLC	SDG No.: Q3448
Project: Linden Generating Station - LRSA	Sample ID: Q3432-01
Client ID: OUTFALL-001DUP	Percent Solids for Spike Sample: 0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
COD	mg/L	+/-20	512	D	522		10	1.93		10/24/2025

Duplicate Sample Summary

Client: Parkway Generation Operating LLC	SDG No.: Q3448
Project: Linden Generating Station - LRSA	Sample ID: Q3432-01
Client ID: OUTFALL-001MSD	Percent Solids for Spike Sample: 0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
COD	mg/L	+/-20	562		552		10	1.8		10/24/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q3448
Project:	Linden Generating Station - LRSA	Sample ID:	Q3448-01
Client ID:	DSN001DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TDS	mg/L	+/-5	1350		1350		1	0.07		10/23/2025
TSS	mg/L	+/-5	27.5		27.1		1	1.47		10/24/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q3448
Project:	Linden Generating Station - LRSA	Sample ID:	Q3448-02
Client ID:	DSN001DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Field pH	pH	+/-20	6.26		6.25		1	0.16		10/23/2025

Duplicate Sample Summary

Client: Parkway Generation Operating LLC	SDG No.: Q3448
Project: Linden Generating Station - LRSA	Sample ID: Q3448-03
Client ID: DSN001DUP	Percent Solids for Spike Sample: 0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/AD	Qual	Analysis Date
Cyanide	mg/L	+/-20	0.0035	J	0.0034	J	1	3		10/24/2025
Phenolics	mg/L	+/-20	0.015	U	0.018	J	1	200	*	10/24/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q3448
Project:	Linden Generating Station - LRSA	Sample ID:	Q3448-03
Client ID:	DSN001MSD	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Cyanide	mg/L	+/-20	0.040		0.040		1	0		10/24/2025
Phenolics	mg/L	+/-20	1.00		1.00		1	0		10/24/2025

Duplicate Sample Summary

Client: Parkway Generation Operating LLC	SDG No.: Q3448
Project: Linden Generating Station - LRSA	Sample ID: Q3448-03
Client ID: DSN001MSD	Percent Solids for Spike Sample: 0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Oil and Grease	mg/L	+/-18	22.4		22.6		1	0.89		10/27/2025

Duplicate Sample Summary

Client: Parkway Generation Operating LLC	SDG No.: Q3448
Project: Linden Generating Station - LRSA	Sample ID: Q3455-01
Client ID: Q3455 -01MSD	Percent Solids for Spike Sample: 0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
Oil and Grease	mg/L	+/-18	287		287		1	0.03		10/27/2025