

Preparation Blank Summary

Client: Parkway Generation Operating LLC

SDG No.: Q3509

Project: Linden Generating Station - LRSA

Analyte	Units	Result	Acceptance Limits	Conc Qual	MDL	RDL	Analysis Date
Sample ID: BOD5	LB137730BL mg/L	< 0.2000	0.2000	U	0.20	2.0	10/31/2025
Sample ID: TSS	LB137737BL mg/L	< 2.0000	2.0000	U	1	4	11/03/2025
Sample ID: COD	LB137760BL mg/L	< 5.0000	5.0000	U	1.5	10.0	11/04/2025