

## Report of Analysis

Client:	NYU Langone Health	Date Collected:	10/31/25
Project:	NYU Clinical Lab Water Testing 2025 - H252243895	Date Received:	10/31/25
Client Sample ID:	TH-404-DI-4	SDG No.:	Q3524
Lab Sample ID:	Q3524-04	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
Dissolved Silica	Dissolved Silica	40.0	U	1	40.0	428	ug/L	11/03/25 10:40	11/05/25 13:53	EPA 200.7	M200.7

U = Not Detected  
 LOQ = Limit of Quantitation  
 MDL = Method Detection Limit  
 LOD = Limit of Detection  
 D = Dilution  
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value  
 B = Analyte Found in Associated Method Blank  
 \* = indicates the duplicate analysis is not within control limits.  
 E = Indicates the reported value is estimated because of the presence of interference.  
 OR = Over Range  
 N = Spiked sample recovery not within control limits