

Duplicate Sample Summary

Client: Major Products Project: Floor Drain Water 2025 Client ID: CompDUP	SDG No.: Q3550 Sample ID: Q3547-02 Percent Solids for Spike Sample: 0
--	--

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
BOD5	mg/L	+/-20	740		740		1	0.09		11/05/2025

Duplicate Sample Summary

Client:	Major Products	SDG No.:	Q3550
Project:	Floor Drain Water 2025	Sample ID:	Q3551-04
Client ID:	MANHOLEDUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TSS	mg/L	+/-5	48.0		48.2		1	0.42		11/07/2025