

Report of Analysis

Client: Pacific Commercial Services Inc.
Project: Kilo Pier
Client Sample ID: 304614-01 fuel
Lab Sample ID: Q3574-03

Date Collected: 11/04/25 08:45
Date Received: 11/07/25
SDG No.: Q3574
Matrix: Water
% Solid: 0

Parameter	Conc.	Qua.	DF	MDL	LOD	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Flash Point	198		1	0	0	0	o F		11/19/25 10:35	1010B

Comments: Other method reference for flash point : Pensky-Martens Closed Cup Flash Point ASTM D 93 - IP 34

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits