

Hit Summary Sheet
SW-846

SDG No.: Q3607

Order ID: Q3607

Client: Total Quality Environmental Inc.

Project ID: Total Quality Environmental Inc

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
Client ID :	Basement Kitchen sink 1st draw							
Q3607-01	Basement Kitchen sink 1st draw	Water	Lead	53.5		1.15	6.00	ug/L
Client ID :	1st Fl drinking fountain 1st drow							
Q3607-03	1st Fl drinking fountain 1st drow	Water	Lead	2.27	J	1.15	6.00	ug/L
Client ID :	1st Fl kids bathroom left sink 1st draw							
Q3607-04	1st Fl kids bathroom left sink 1st	Water	Lead	1.46	J	1.15	6.00	ug/L
Client ID :	1st Fl kids right 1st draw							
Q3607-06	1st Fl kids right 1st draw	Water	Lead	79.3		1.15	6.00	ug/L
Client ID :	main hall right sink 1st draw							
Q3607-07	main hall right sink 1st draw	Water	Lead	7.42		1.15	6.00	ug/L
Client ID :	main hall left sink 1st draw							
Q3607-09	main hall left sink 1st draw	Water	Lead	1.49	J	1.15	6.00	ug/L