

Hit Summary Sheet
SW-846

SDG No.:	Q3607	Order ID:	Q3607
Client:	Total Quality Environmental Inc.	Project ID:	Total Quality Environmental Inc

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
Client ID :	Basement Kitchen sink 1st draw							
Q3607-01	Basement Kitchen sink 1st draw	Water	Lead	53.5		1.15	6.00	ug/L
Client ID :	1st Fl drinking fountain 1st drow							
Q3607-03	1st Fl drinking fountain 1st drow	Water	Lead	2.27	J	1.15	6.00	ug/L
Client ID :	1st Fl kids bathroom left sink 1st draw							
Q3607-04	1st Fl kids bathroom left sink 1st	Water	Lead	1.46	J	1.15	6.00	ug/L
Client ID :	1st Fl kids right 1st draw							
Q3607-06	1st Fl kids right 1st draw	Water	Lead	79.3		1.15	6.00	ug/L
Client ID :	main hall right sink 1st draw							
Q3607-07	main hall right sink 1st draw	Water	Lead	7.42		1.15	6.00	ug/L
Client ID :	main hall left sink 1st draw							
Q3607-09	main hall left sink 1st draw	Water	Lead	1.49	J	1.15	6.00	ug/L



SAMPLE DATA

A

B

C

D

Report of Analysis

Client: Total Quality Environmental Inc.
Project: Total Quality Environmental Inc
Client Sample ID: Basement Kitchen sink 1st draw
Lab Sample ID: Q3607-01
Level (low/med): low

Date Collected: 11/11/25
Date Received: 11/11/25
SDG No.: Q3607
Matrix: Water
% Solid: 0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	53.5	1	1.15		6.00	ug/L	11/12/25 11:02	11/12/25 21:07	6010D	M3010A

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	11/11/25
Project:	Total Quality Environmental Inc	Date Received:	11/11/25
Client Sample ID:	1st Fl adult bathroom sink 1st draw	SDG No.:	Q3607
Lab Sample ID:	Q3607-02	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.15	U	1	1.15	6.00	ug/L	11/12/25 11:02	11/12/25 21:11	6010D	M3010A

U = Not Detected
 LOQ = Limit of Quantitation
 MDL = Method Detection Limit
 LOD = Limit of Detection
 D = Dilution
 Q = indicates LCS control criteria did not meet requirements

J = Estimated Value
 B = Analyte Found in Associated Method Blank
 * = indicates the duplicate analysis is not within control limits.
 E = Indicates the reported value is estimated because of the presence of interference.
 OR = Over Range
 N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	11/11/25
Project:	Total Quality Environmental Inc	Date Received:	11/11/25
Client Sample ID:	1st Fl drinking fountain 1st drow	SDG No.:	Q3607
Lab Sample ID:	Q3607-03	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	2.27	J	1	1.15	6.00	ug/L	11/12/25 11:02	11/12/25 21:15	6010D	M3010A

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	11/11/25
Project:	Total Quality Environmental Inc	Date Received:	11/11/25
Client Sample ID:	1st Fl kids bathroom left sink 1st draw	SDG No.:	Q3607
Lab Sample ID:	Q3607-04	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.46	J	1	1.15	6.00	ug/L	11/12/25 11:02	11/12/25 21:29	6010D	M3010A

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	11/11/25
Project:	Total Quality Environmental Inc	Date Received:	11/11/25
Client Sample ID:	1st Fl kids bathroom left sink 2nd draw	SDG No.:	Q3607
Lab Sample ID:	Q3607-05	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.15	U	1	1.15	6.00	ug/L	11/12/25 11:02	11/12/25 21:34	6010D	M3010A

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	11/11/25
Project:	Total Quality Environmental Inc	Date Received:	11/11/25
Client Sample ID:	1st Fl kids right 1st draw	SDG No.:	Q3607
Lab Sample ID:	Q3607-06	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	79.3	1	1.15		6.00	ug/L	11/12/25 11:02	11/12/25 21:38	6010D	M3010A

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	11/11/25
Project:	Total Quality Environmental Inc	Date Received:	11/11/25
Client Sample ID:	main hall right sink 1st draw	SDG No.:	Q3607
Lab Sample ID:	Q3607-07	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	7.42	1	1.15		6.00	ug/L	11/12/25 11:02	11/12/25 21:42	6010D	M3010A

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	11/11/25
Project:	Total Quality Environmental Inc	Date Received:	11/11/25
Client Sample ID:	main hall right sink 2nd draw	SDG No.:	Q3607
Lab Sample ID:	Q3607-08	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.15	U	1	1.15	6.00	ug/L	11/12/25 11:02	11/12/25 22:24	6010D	M3010A

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	11/11/25
Project:	Total Quality Environmental Inc	Date Received:	11/11/25
Client Sample ID:	main hall left sink 1st draw	SDG No.:	Q3607
Lab Sample ID:	Q3607-09	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	1.49	J	1	1.15	6.00	ug/L	11/12/25 11:02	11/12/25 22:28	6010D	M3010A

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits

LAB CHRONICLE

OrderID:	Q3607	OrderDate:	11/11/2025 2:47:00 PM
Client:	Total Quality Environmental Inc.	Project:	Total Quality Environmental Inc
Contact:	Alex Rukasov	Location:	J11

LabID	ClientID	Matrix	Test	Method	Sample Date	Prep Date	Anal Date	Received
Q3607-01	Basement Kitchen sink 1st draw	Water			11/11/25			11/11/25
			Metals Group3	6010D		11/12/25	11/12/25	
Q3607-02	1st Fl adult bathroom sink 1st draw	Water			11/11/25			11/11/25
			Metals Group3	6010D		11/12/25	11/12/25	
Q3607-03	1st Fl drinking fountain 1st draw	Water			11/11/25			11/11/25
			Metals Group3	6010D		11/12/25	11/12/25	
Q3607-04	1st Fl kids bathroom left sink 1st draw	Water			11/11/25			11/11/25
			Metals Group3	6010D		11/12/25	11/12/25	
Q3607-05	1st Fl kids bathroom left sink 2nd draw	Water			11/11/25			11/11/25
			Metals Group3	6010D		11/12/25	11/12/25	
Q3607-06	1st Fl kids right 1st draw	Water			11/11/25			11/11/25
			Metals Group3	6010D		11/12/25	11/12/25	
Q3607-07	main hall right sink 1st draw	Water			11/11/25			11/11/25
			Metals Group3	6010D		11/12/25	11/12/25	
Q3607-08	main hall right sink 2nd draw	Water			11/11/25			11/11/25
			Metals Group3	6010D		11/12/25	11/12/25	
Q3607-09	main hall left sink 1st draw	Water			11/11/25			11/11/25
			Metals Group3	6010D		11/12/25	11/12/25	