

Preparation Blank Summary

Client: Dal-Tile

SDG No.: Q3616

Project: Waste Water - Dickson Plant

Analyte	Units	Result	Acceptance Limits	Conc Qual	MDL	RDL	Analysis Date
Sample ID: LB137875BL Hexavalent Chromium	mg/L	< 0.0050	0.0050	U	0.003	0.01	11/12/2025
Sample ID: LB137877BL Oil and Grease	mg/L	< 2.5000	2.5000	U	0.29	5.0	11/13/2025
Sample ID: LB137907BL BOD5	mg/L	< 0.2000	0.2000	U	0.20	2.0	11/13/2025
Sample ID: LB137913BL TSS	mg/L	< 2.0000	2.0000	U	1	4	11/17/2025
Sample ID: PB170548BL Cyanide	mg/L	< 0.0025	0.0025	U	0.0012	0.005	11/14/2025
Sample ID: PB170582BL Ammonia as N	mg/L	< 0.0500	0.0500	U	0.03	0.1	11/17/2025
Sample ID: PB170686BL Phosphorus, Total	mg/L	0.008	0.0250	J	0.005	0.05	11/21/2025