

Duplicate Sample Summary

Client: Parkway Generation Operating LLC Project: Linden Generating Station - Towers Client ID: TOWER-1DUP	SDG No.: Q3629 Sample ID: Q3629-01 Percent Solids for Spike Sample: 0
---	--

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TDS	mg/L	+/-5	3260		3260		1	0.12		11/13/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q3629
Project:	Linden Generating Station - Towers	Sample ID:	Q3630-05
Client ID:	DSN003DUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TSS	mg/L	+/-5	4.00		4.00		1	0		11/17/2025