

Report of Analysis

Client: Parkway Generation Operating LLC
Project: Linden Generating Station - LRSA
Client Sample ID: DSN001
Lab Sample ID: Q3630-03

Date Collected: 11/13/25 09:20
Date Received: 11/13/25
SDG No.: Q3630
Matrix: WATER
% Solid: 0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Ammonia as N	0.18		1	0.030	0.10	mg/L	11/17/25 08:45	11/17/25 13:20	SM 4500-NH3 B plus G-21
BOD5	2.00	U	1	0.20	2.00	mg/L		11/14/25 15:30	SM 5210 B-16
COD	84.6		1	1.50	10.0	mg/L		11/14/25 14:10	SM 5220 D-11
TSS	42.5		1	1.00	4.00	mg/L		11/17/25 12:30	SM 2540 D-20

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits