

Report of Analysis

Client: Parkway Generation Operating LLC
Project: Linden Generating Station - LRSA
Client Sample ID: DSN003
Lab Sample ID: Q3630-05
Level (low/med): low

Date Collected: 11/13/25
Date Received: 11/13/25
SDG No.: Q3630
Matrix: Water
% Solid: 0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7440-38-2	Arsenic	10.0	U	1	2.56	10.0	ug/L	11/14/25 10:30	11/17/25 16:30	6010D	M3010A
7440-43-9	Cadmium	3.00	U	1	0.25	3.00	ug/L	11/14/25 10:30	11/17/25 16:30	6010D	M3010A
7440-47-3	Chromium	6.18		1	1.06	5.00	ug/L	11/14/25 10:30	11/17/25 16:30	6010D	M3010A
7440-50-8	Copper	2.79	J	1	2.30	10.0	ug/L	11/14/25 10:30	11/17/25 16:30	6010D	M3010A
7439-89-6	Iron	136		1	11.7	50.0	ug/L	11/14/25 10:30	11/17/25 16:30	6010D	M3010A
7439-92-1	Lead	6.00	U	1	1.15	6.00	ug/L	11/14/25 10:30	11/17/25 16:30	6010D	M3010A
7440-02-0	Nickel	12.1	J	1	1.53	20.0	ug/L	11/14/25 10:30	11/17/25 16:30	6010D	M3010A
7440-66-6	Zinc	79.5		1	8.33	20.0	ug/L	11/14/25 10:30	11/17/25 16:30	6010D	M3010A

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits