

Report of Analysis

Client: Parkway Generation Operating LLC
Project: Linden Gen - NJDEP WW Discharge Permit
Client Sample ID: TANK-1-COMP-2
Lab Sample ID: Q3659-02

Date Collected: 11/17/25 10:34
Date Received: 11/17/25
SDG No.: Q3659
Matrix: SOIL
% Solid: 99.7

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Corrosivity	6.67	H	1	0	0	pH		11/18/25 12:00	9045D
Hexavalent Chromium	0.40	U	1	0.070	0.40	mg/Kg	11/19/25 09:00	11/19/25 13:22	7196A
Ignitability	NO		1	0	0	oC		11/18/25 10:17	1030
Reactive Cyanide	0.049	U	1	0.0083	0.049	mg/Kg	11/17/25 16:00	11/18/25 10:16	9012B
Reactive Sulfide	3.17	J	1	0.20	10.0	mg/Kg	11/18/25 14:10	11/18/25 16:31	9034

Comments: pH result reported at temperature 21.6 °C

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits