



284 Sheffield Street, Mountainside, New Jersey 07092, Phone : 908 789 8900,
Fax : 908 789 8922

Hit Summary Sheet
SW-846

SDG No.: Q3717

Order ID: Q3717

Client: ATC Group Services LLC

Project ID: JHS

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
Client ID :				Total Concentration:	0.000			



SAMPLE DATA

A

B

C

D

Report of Analysis

Client:	ATC Group Services LLC		Date Collected:	11/24/25
Project:	JHS		Date Received:	11/24/25
Client Sample ID:	1A1B1C		SDG No.:	Q3717
Lab Sample ID:	Q3717-01		Matrix:	CAULK
Analytical Method:	8082A		% Solid:	100
Sample Wt/Vol:	1.9 g	Final Vol: 10000 uL	Test:	PCB Group1
Prep Method:	SW3541B	Prep Date: 11/25/25		

CAS Number	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Date Ana.	BatchID
TARGETS									
12674-11-2	Aroclor-1016	624	U	10	624	2700	ug/kg	11/25/25 14:48	PB170728
11104-28-2	Aroclor-1221	636	U	10	636	2700	ug/kg	11/25/25 14:48	PB170728
11141-16-5	Aroclor-1232	587	U	10	587	2700	ug/kg	11/25/25 14:48	PB170728
53469-21-9	Aroclor-1242	633	U	10	633	2700	ug/kg	11/25/25 14:48	PB170728
12672-29-6	Aroclor-1248	935	U	10	935	2700	ug/kg	11/25/25 14:48	PB170728
11097-69-1	Aroclor-1254	507	U	10	507	2700	ug/kg	11/25/25 14:48	PB170728
37324-23-5	Aroclor-1262	793	U	10	793	2700	ug/kg	11/25/25 14:48	PB170728
11100-14-4	Aroclor-1268	568	U	10	568	2700	ug/kg	11/25/25 14:48	PB170728
11096-82-5	Aroclor-1260	510	U	10	510	2700	ug/kg	11/25/25 14:48	PB170728
Total PCBs	Total PCBs	935	U	10	935	2700	ug/kg	11/25/25 14:48	PB170728
SURROGATES									
877-09-8	Tetrachloro-m-xylene	21.9			21 - 165	110%	SPK: 20		
2051-24-3	Decachlorobiphenyl	20.1			10 - 170	101%	SPK: 20		

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

E = Value Exceeds Calibration Range

P = Indicates >25% difference for detected concentrations between the two GC columns

Q = indicates LCS control criteria did not meet requirements

M = MS/MSD acceptance criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

N = Presumptive Evidence of a Compound

* = Values outside of QC limits

D = Dilution

S = Indicates estimated value where valid five-point calibration was not performed prior to analyte detection in sample.

() = Laboratory InHouse Limit

Report of Analysis

Client:	ATC Group Services LLC		Date Collected:	11/24/25
Project:	JHS		Date Received:	11/24/25
Client Sample ID:	2A2B2C		SDG No.:	Q3717
Lab Sample ID:	Q3717-02		Matrix:	CAULK
Analytical Method:	8082A		% Solid:	100
Sample Wt/Vol:	1.39 g	Final Vol: 10000 uL	Test:	PCB Group1
Prep Method:	SW3541B	Prep Date: 11/25/25		

CAS Number	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Date Ana.	BatchID
TARGETS									
12674-11-2	Aroclor-1016	853	U	10	853	3700	ug/kg	11/25/25 15:03	PB170728
11104-28-2	Aroclor-1221	870	U	10	870	3700	ug/kg	11/25/25 15:03	PB170728
11141-16-5	Aroclor-1232	803	U	10	803	3700	ug/kg	11/25/25 15:03	PB170728
53469-21-9	Aroclor-1242	865	U	10	865	3700	ug/kg	11/25/25 15:03	PB170728
12672-29-6	Aroclor-1248	1300	U	10	1300	3700	ug/kg	11/25/25 15:03	PB170728
11097-69-1	Aroclor-1254	693	U	10	693	3700	ug/kg	11/25/25 15:03	PB170728
37324-23-5	Aroclor-1262	1100	U	10	1100	3700	ug/kg	11/25/25 15:03	PB170728
11100-14-4	Aroclor-1268	777	U	10	777	3700	ug/kg	11/25/25 15:03	PB170728
11096-82-5	Aroclor-1260	697	U	10	697	3700	ug/kg	11/25/25 15:03	PB170728
Total PCBs	Total PCBs	1300	U	10	1300	3700	ug/kg	11/25/25 15:03	PB170728
SURROGATES									
877-09-8	Tetrachloro-m-xylene	18.3			21 - 165	92%	SPK: 20		
2051-24-3	Decachlorobiphenyl	16.1			10 - 170	81%	SPK: 20		

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

E = Value Exceeds Calibration Range

P = Indicates >25% difference for detected concentrations between the two GC columns

Q = indicates LCS control criteria did not meet requirements

M = MS/MSD acceptance criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

N = Presumptive Evidence of a Compound

* = Values outside of QC limits

D = Dilution

S = Indicates estimated value where valid five-point calibration was not performed prior to analyte detection in sample.

() = Laboratory InHouse Limit

Report of Analysis

Client:	ATC Group Services LLC		Date Collected:	11/24/25
Project:	JHS		Date Received:	11/24/25
Client Sample ID:	3A3B3C		SDG No.:	Q3717
Lab Sample ID:	Q3717-03		Matrix:	CAULK
Analytical Method:	8082A		% Solid:	100
Sample Wt/Vol:	1.08 g	Final Vol: 10000 uL	Test:	PCB Group1
Prep Method:	SW3541B	Prep Date: 11/25/25		

CAS Number	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Date Ana.	BatchID
TARGETS									
12674-11-2	Aroclor-1016	1100	U	10	1100	4700	ug/kg	11/25/25 15:18	PB170728
11104-28-2	Aroclor-1221	1100	U	10	1100	4700	ug/kg	11/25/25 15:18	PB170728
11141-16-5	Aroclor-1232	1000	U	10	1000	4700	ug/kg	11/25/25 15:18	PB170728
53469-21-9	Aroclor-1242	1100	U	10	1100	4700	ug/kg	11/25/25 15:18	PB170728
12672-29-6	Aroclor-1248	1600	U	10	1600	4700	ug/kg	11/25/25 15:18	PB170728
11097-69-1	Aroclor-1254	892	U	10	892	4700	ug/kg	11/25/25 15:18	PB170728
37324-23-5	Aroclor-1262	1400	U	10	1400	4700	ug/kg	11/25/25 15:18	PB170728
11100-14-4	Aroclor-1268	1000	U	10	1000	4700	ug/kg	11/25/25 15:18	PB170728
11096-82-5	Aroclor-1260	897	U	10	897	4700	ug/kg	11/25/25 15:18	PB170728
Total PCBs	Total PCBs	1600	U	10	1600	4700	ug/kg	11/25/25 15:18	PB170728
SURROGATES									
877-09-8	Tetrachloro-m-xylene	22.3			21 - 165	112%	SPK: 20		
2051-24-3	Decachlorobiphenyl	21.0			10 - 170	105%	SPK: 20		

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

E = Value Exceeds Calibration Range

P = Indicates >25% difference for detected concentrations between the two GC columns

Q = indicates LCS control criteria did not meet requirements

M = MS/MSD acceptance criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

N = Presumptive Evidence of a Compound

* = Values outside of QC limits

D = Dilution

S = Indicates estimated value where valid five-point calibration was not performed prior to analyte detection in sample.

() = Laboratory InHouse Limit

Report of Analysis

Client:	ATC Group Services LLC		Date Collected:	11/24/25
Project:	JHS		Date Received:	11/24/25
Client Sample ID:	4A4B4C		SDG No.:	Q3717
Lab Sample ID:	Q3717-04		Matrix:	CAULK
Analytical Method:	8082A		% Solid:	100
Sample Wt/Vol:	2.2 g	Final Vol: 10000 uL	Test:	PCB Group1
Prep Method:	SW3541B	Prep Date: 11/25/25		

CAS Number	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Date Ana.	BatchID
TARGETS									
12674-11-2	Aroclor-1016	539	U	10	539	2300	ug/kg	11/25/25 15:32	PB170728
11104-28-2	Aroclor-1221	550	U	10	550	2300	ug/kg	11/25/25 15:32	PB170728
11141-16-5	Aroclor-1232	507	U	10	507	2300	ug/kg	11/25/25 15:32	PB170728
53469-21-9	Aroclor-1242	547	U	10	547	2300	ug/kg	11/25/25 15:32	PB170728
12672-29-6	Aroclor-1248	807	U	10	807	2300	ug/kg	11/25/25 15:32	PB170728
11097-69-1	Aroclor-1254	438	U	10	438	2300	ug/kg	11/25/25 15:32	PB170728
37324-23-5	Aroclor-1262	685	U	10	685	2300	ug/kg	11/25/25 15:32	PB170728
11100-14-4	Aroclor-1268	491	U	10	491	2300	ug/kg	11/25/25 15:32	PB170728
11096-82-5	Aroclor-1260	440	U	10	440	2300	ug/kg	11/25/25 15:32	PB170728
Total PCBs	Total PCBs	807	U	10	807	2300	ug/kg	11/25/25 15:32	PB170728
SURROGATES									
877-09-8	Tetrachloro-m-xylene	22.4			21 - 165	112%	SPK: 20		
2051-24-3	Decachlorobiphenyl	20.4			10 - 170	102%	SPK: 20		

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

E = Value Exceeds Calibration Range

P = Indicates >25% difference for detected concentrations between the two GC columns

Q = indicates LCS control criteria did not meet requirements

M = MS/MSD acceptance criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

N = Presumptive Evidence of a Compound

* = Values outside of QC limits

D = Dilution

S = Indicates estimated value where valid five-point calibration was not performed prior to analyte detection in sample.

() = Laboratory InHouse Limit

Report of Analysis

Client:	ATC Group Services LLC		Date Collected:	11/24/25
Project:	JHS		Date Received:	11/24/25
Client Sample ID:	5A5B5C		SDG No.:	Q3717
Lab Sample ID:	Q3717-05		Matrix:	CAULK
Analytical Method:	8082A		% Solid:	100
Sample Wt/Vol:	4.2 g	Final Vol: 10000 uL	Test:	PCB Group1
Prep Method:	SW3541B		Prep Date:	11/25/25

CAS Number	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Date Ana.	BatchID
TARGETS									
12674-11-2	Aroclor-1016	282	U	10	282	1200	ug/kg	11/25/25 15:47	PB170728
11104-28-2	Aroclor-1221	288	U	10	288	1200	ug/kg	11/25/25 15:47	PB170728
11141-16-5	Aroclor-1232	266	U	10	266	1200	ug/kg	11/25/25 15:47	PB170728
53469-21-9	Aroclor-1242	286	U	10	286	1200	ug/kg	11/25/25 15:47	PB170728
12672-29-6	Aroclor-1248	423	U	10	423	1200	ug/kg	11/25/25 15:47	PB170728
11097-69-1	Aroclor-1254	229	U	10	229	1200	ug/kg	11/25/25 15:47	PB170728
37324-23-5	Aroclor-1262	359	U	10	359	1200	ug/kg	11/25/25 15:47	PB170728
11100-14-4	Aroclor-1268	257	U	10	257	1200	ug/kg	11/25/25 15:47	PB170728
11096-82-5	Aroclor-1260	231	U	10	231	1200	ug/kg	11/25/25 15:47	PB170728
Total PCBs	Total PCBs	423	U	10	423	1200	ug/kg	11/25/25 15:47	PB170728
SURROGATES									
877-09-8	Tetrachloro-m-xylene	22.1			21 - 165	111%	SPK: 20		
2051-24-3	Decachlorobiphenyl	28.4			10 - 170	142%	SPK: 20		

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

E = Value Exceeds Calibration Range

P = Indicates >25% difference for detected concentrations between the two GC columns

Q = indicates LCS control criteria did not meet requirements

M = MS/MSD acceptance criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

N = Presumptive Evidence of a Compound

* = Values outside of QC limits

D = Dilution

S = Indicates estimated value where valid five-point calibration was not performed prior to analyte detection in sample.

() = Laboratory InHouse Limit

Report of Analysis

Client:	ATC Group Services LLC		Date Collected:	11/24/25
Project:	JHS		Date Received:	11/24/25
Client Sample ID:	6A6B6C		SDG No.:	Q3717
Lab Sample ID:	Q3717-06		Matrix:	CAULK
Analytical Method:	8082A		% Solid:	100
Sample Wt/Vol:	1.73 g	Final Vol: 10000 uL	Test:	PCB Group1
Prep Method:	SW3541B	Prep Date: 11/25/25		

CAS Number	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Date Ana.	BatchID
TARGETS									
12674-11-2	Aroclor-1016	685	U	10	685	2900	ug/kg	11/25/25 16:01	PB170728
11104-28-2	Aroclor-1221	699	U	10	699	2900	ug/kg	11/25/25 16:01	PB170728
11141-16-5	Aroclor-1232	645	U	10	645	2900	ug/kg	11/25/25 16:01	PB170728
53469-21-9	Aroclor-1242	695	U	10	695	2900	ug/kg	11/25/25 16:01	PB170728
12672-29-6	Aroclor-1248	1000	U	10	1000	2900	ug/kg	11/25/25 16:01	PB170728
11097-69-1	Aroclor-1254	557	U	10	557	2900	ug/kg	11/25/25 16:01	PB170728
37324-23-5	Aroclor-1262	871	U	10	871	2900	ug/kg	11/25/25 16:01	PB170728
11100-14-4	Aroclor-1268	624	U	10	624	2900	ug/kg	11/25/25 16:01	PB170728
11096-82-5	Aroclor-1260	560	U	10	560	2900	ug/kg	11/25/25 16:01	PB170728
Total PCBs	Total PCBs	1000	U	10	1000	2900	ug/kg	11/25/25 16:01	PB170728
SURROGATES									
877-09-8	Tetrachloro-m-xylene	23.4			21 - 165	117%	SPK: 20		
2051-24-3	Decachlorobiphenyl	21.4			10 - 170	107%	SPK: 20		

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

E = Value Exceeds Calibration Range

P = Indicates >25% difference for detected concentrations between the two GC columns

Q = indicates LCS control criteria did not meet requirements

M = MS/MSD acceptance criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

N = Presumptive Evidence of a Compound

* = Values outside of QC limits

D = Dilution

S = Indicates estimated value where valid five-point calibration was not performed prior to analyte detection in sample.

() = Laboratory InHouse Limit

Report of Analysis

Client:	ATC Group Services LLC		Date Collected:	11/24/25
Project:	JHS		Date Received:	11/24/25
Client Sample ID:	7A7B7C		SDG No.:	Q3717
Lab Sample ID:	Q3717-07		Matrix:	CAULK
Analytical Method:	8082A		% Solid:	100
Sample Wt/Vol:	4.12 g	Final Vol: 10000 uL	Test:	PCB Group1
Prep Method:	SW3541B	Prep Date: 11/25/25		

CAS Number	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Date Ana.	BatchID
TARGETS									
12674-11-2	Aroclor-1016	288	U	10	288	1200	ug/kg	11/25/25 16:16	PB170728
11104-28-2	Aroclor-1221	293	U	10	293	1200	ug/kg	11/25/25 16:16	PB170728
11141-16-5	Aroclor-1232	271	U	10	271	1200	ug/kg	11/25/25 16:16	PB170728
53469-21-9	Aroclor-1242	292	U	10	292	1200	ug/kg	11/25/25 16:16	PB170728
12672-29-6	Aroclor-1248	431	U	10	431	1200	ug/kg	11/25/25 16:16	PB170728
11097-69-1	Aroclor-1254	234	U	10	234	1200	ug/kg	11/25/25 16:16	PB170728
37324-23-5	Aroclor-1262	366	U	10	366	1200	ug/kg	11/25/25 16:16	PB170728
11100-14-4	Aroclor-1268	262	U	10	262	1200	ug/kg	11/25/25 16:16	PB170728
11096-82-5	Aroclor-1260	235	U	10	235	1200	ug/kg	11/25/25 16:16	PB170728
Total PCBs	Total PCBs	431	U	10	431	1200	ug/kg	11/25/25 16:16	PB170728
SURROGATES									
877-09-8	Tetrachloro-m-xylene	22.3			21 - 165	112%	SPK: 20		
2051-24-3	Decachlorobiphenyl	28.7			10 - 170	144%	SPK: 20		

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

E = Value Exceeds Calibration Range

P = Indicates >25% difference for detected concentrations between the two GC columns

Q = indicates LCS control criteria did not meet requirements

M = MS/MSD acceptance criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

N = Presumptive Evidence of a Compound

* = Values outside of QC limits

D = Dilution

S = Indicates estimated value where valid five-point calibration was not performed prior to analyte detection in sample.

() = Laboratory InHouse Limit

Report of Analysis

Client:	ATC Group Services LLC		Date Collected:	11/24/25
Project:	JHS		Date Received:	11/24/25
Client Sample ID:	8A8B8C		SDG No.:	Q3717
Lab Sample ID:	Q3717-08		Matrix:	CAULK
Analytical Method:	8082A		% Solid:	100
Sample Wt/Vol:	2.11 g	Final Vol: 10000 uL	Test:	PCB Group1
Prep Method:	SW3541B	Prep Date: 11/25/25		

CAS Number	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Date Ana.	BatchID
TARGETS									
12674-11-2	Aroclor-1016	562	U	10	562	2400	ug/kg	11/25/25 16:30	PB170728
11104-28-2	Aroclor-1221	573	U	10	573	2400	ug/kg	11/25/25 16:30	PB170728
11141-16-5	Aroclor-1232	529	U	10	529	2400	ug/kg	11/25/25 16:30	PB170728
53469-21-9	Aroclor-1242	570	U	10	570	2400	ug/kg	11/25/25 16:30	PB170728
12672-29-6	Aroclor-1248	842	U	10	842	2400	ug/kg	11/25/25 16:30	PB170728
11097-69-1	Aroclor-1254	456	U	10	456	2400	ug/kg	11/25/25 16:30	PB170728
37324-23-5	Aroclor-1262	714	U	10	714	2400	ug/kg	11/25/25 16:30	PB170728
11100-14-4	Aroclor-1268	512	U	10	512	2400	ug/kg	11/25/25 16:30	PB170728
11096-82-5	Aroclor-1260	459	U	10	459	2400	ug/kg	11/25/25 16:30	PB170728
Total PCBs	Total PCBs	842	U	10	842	2400	ug/kg	11/25/25 16:30	PB170728
SURROGATES									
877-09-8	Tetrachloro-m-xylene	25.9			21 - 165	130%	SPK: 20		
2051-24-3	Decachlorobiphenyl	27.4			10 - 170	137%	SPK: 20		

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

E = Value Exceeds Calibration Range

P = Indicates >25% difference for detected concentrations between the two GC columns

Q = indicates LCS control criteria did not meet requirements

M = MS/MSD acceptance criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

N = Presumptive Evidence of a Compound

* = Values outside of QC limits

D = Dilution

S = Indicates estimated value where valid five-point calibration was not performed prior to analyte detection in sample.

() = Laboratory InHouse Limit

LAB CHRONICLE

OrderID:	Q3717	OrderDate:	11/24/2025 3:44:23 PM
Client:	ATC Group Services LLC	Project:	JHS
Contact:	Olga Seldinas	Location:	A11

LabID	ClientID	Matrix	Test	Method	Sample Date	Prep Date	Anal Date	Received
Q3717-01	1A1B1C	CAULK	PCB Group1	8082A	11/24/25	11/25/25	11/25/25	11/24/25
Q3717-02	2A2B2C	CAULK	PCB Group1	8082A	11/24/25	11/25/25	11/25/25	11/24/25
Q3717-03	3A3B3C	CAULK	PCB Group1	8082A	11/24/25	11/25/25	11/25/25	11/24/25
Q3717-04	4A4B4C	CAULK	PCB Group1	8082A	11/24/25	11/25/25	11/25/25	11/24/25
Q3717-05	5A5B5C	CAULK	PCB Group1	8082A	11/24/25	11/25/25	11/25/25	11/24/25
Q3717-06	6A6B6C	CAULK	PCB Group1	8082A	11/24/25	11/25/25	11/25/25	11/24/25
Q3717-07	7A7B7C	CAULK	PCB Group1	8082A	11/24/25	11/25/25	11/25/25	11/24/25
Q3717-08	8A8B8C	CAULK	PCB Group1	8082A	11/24/25	11/25/25	11/25/25	11/24/25