

Report of Analysis

Client:	Total Quality Environmental Inc.	Date Collected:	11/24/25
Project:	Total Quality Environmental Inc	Date Received:	11/25/25
Client Sample ID:	Drinking Fountain (1st draw)	SDG No.:	Q3718
Lab Sample ID:	Q3718-05	Matrix:	Water
Level (low/med):	low	% Solid:	0

Cas	Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.	Prep Met.
7439-92-1	Lead	4.85	J	1	1.15	6.00	ug/L	11/25/25 10:50	11/26/25 17:37	6010D	M3010A

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits