

Hit Summary Sheet
SW-846

SDG No.: Q3718

Order ID: Q3718

Client: Total Quality Environmental Inc.

Project ID: Total Quality Environmental Inc

Sample ID	Client ID	Matrix	Parameter	Concentration	C	MDL	RDL	Units
Client ID :	Basement Kitchen (1st draw)							
Q3718-01	Basement Kitchen (1st draw)	Water	Lead	43.3		1.15	6.00	ug/L
Client ID :	2nd draw							
Q3718-02	2nd draw	Water	Lead	70.0		1.15	6.00	ug/L
Client ID :	Adult Bathroom (1st draw)							
Q3718-03	Adult Bathroom (1st draw)	Water	Lead	39.7		1.15	6.00	ug/L
Client ID :	2nd draw							
Q3718-04	2nd draw	Water	Lead	65.1		1.15	6.00	ug/L
Client ID :	Drinking Fountain (1st draw)							
Q3718-05	Drinking Fountain (1st draw)	Water	Lead	4.85	J	1.15	6.00	ug/L
Client ID :	2nd draw							
Q3718-06	2nd draw	Water	Lead	9.63		1.15	6.00	ug/L
Client ID :	Kids Bathroom L (1st draw)							
Q3718-07	Kids Bathroom L (1st draw)	Water	Lead	157		1.15	6.00	ug/L
Client ID :	L 2nd draw							
Q3718-08	L 2nd draw	Water	Lead	35.8		1.15	6.00	ug/L
Client ID :	R (1st draw)							
Q3718-09	R (1st draw)	Water	Lead	117		1.15	6.00	ug/L
Client ID :	R (2nd draw)							
Q3718-10	R (2nd draw)	Water	Lead	2.99	J	1.15	6.00	ug/L
Client ID :	Main Hall L (1st draw)							
Q3718-11	Main Hall L (1st draw)	Water	Lead	18.9		1.15	6.00	ug/L
Client ID :	L (2nd draw)							
Q3718-12	L (2nd draw)	Water	Lead	131		1.15	6.00	ug/L
Client ID :	R (1st draw)							
Q3718-13	R (1st draw)	Water	Lead	110		1.15	6.00	ug/L
Client ID :	R (2nd draw)							
Q3718-14	R (2nd draw)	Water	Lead	10.2		1.15	6.00	ug/L