

## Report of Bacteriological Examination (Heterotrophic Plate Count)

**Client:** Alliance Technical Group  
**Collected/Submitted by:** Client  
**Project Name/No.:** NYU Clinical Lab Water Testing 2025 - H25224389 / Q3724  
**Project Address:**  
**Matrix:** Water

**Lab ID:** HP1125050  
**Date Received:** 11/25/2025  
**Time Received:** 16:58  
**Report Date:** 11/28/2025

Sample ID#	Sample Collected	Location/Description	Incubation in/out	HPC (cfu/ml)
Client ID#	Date/Time		Date/Time	
01	*10/31/2025 @ 11:30	TH-401A-SINK-1	Incubated in: 11/25/2025 @ 17:31	4
HP1125050-1			Incubated out: 11/27/2025 @ 17:31	
02	*10/31/2025 @ 11:30	TH-403A-SINK-2	Incubated in: 11/25/2025 @ 17:31	11
HP1125050-2			Incubated out: 11/27/2025 @ 17:31	
03	*10/31/2025 @ 12:00	CC-10TH-FL	Incubated in: 11/25/2025 @ 17:31	22
HP1125050-3			Incubated out: 11/27/2025 @ 17:31	
04	*10/31/2025 @ 12:15	CC-3RD-FL	Incubated in: 11/25/2025 @ 17:31	6
HP1125050-4			Incubated out: 11/27/2025 @ 17:31	
05	*10/31/2025 @ 12:15	7N-SKIRBALL	Incubated in: 11/25/2025 @ 17:31	5
HP1125050-5			Incubated out: 11/27/2025 @ 17:31	
06	*10/31/2025 @ 12:15	TH-430-D1-1	Incubated in: 11/25/2025 @ 17:31	8
HP1125050-6			Incubated out: 11/27/2025 @ 17:31	
07	*10/31/2025 @ 12:15	TH-430-D1-2	Incubated in: 11/25/2025 @ 17:31	190
HP1125050-7			Incubated out: 11/27/2025 @ 17:31	

## Report of Bacteriological Examination (Heterotrophic Plate Count)

**Client:** Alliance Technical Group  
**Collected/Submitted by:** Client  
**Project Name/No.:** NYU Clinical Lab Water Testing 2025 - H25224389 / Q3724  
**Project Address:**  
**Matrix:** Water

**Lab ID:** HP1125050  
**Date Received:** 11/25/2025  
**Time Received:** 16:58  
**Report Date:** 11/28/2025

Sample ID#	Sample Collected	Location/Description	Incubation in/out	HPC (cfu/ml)
Client ID#	Date/Time		Date/Time	
08	*10/31/2025 @ 12:15	TH-430-D1-3	Incubated in: 11/25/2025 @ 17:31	440
HP1125050-8			Incubated out: 11/27/2025 @ 17:31	
09	*10/31/2025 @ 12:15	TH-404-D1-4	Incubated in: 11/25/2025 @ 17:31	2
HP1125050-9			Incubated out: 11/27/2025 @ 17:31	

AH

*\*Sampling date on the COC differs from the sampling date on the samples (11/25/2025). Holding time is 48 hours; otherwise, it will be out of holding time.*

Method: Potable: SM 20, 21-23 9215 B (-04); Non Potable: SM 18-21 9215 B

ELAP Method 9136

Analyst: JD

Approved by: 

This laboratory report may not be reproduced, except in full, without the written approval of Atlas Environmental Lab corp.

Results relate only to the items tested.

NYS-ELAP#11999