



# SAMPLE DATA

A

B

C

## Report of Analysis

Client: Tully Environmental, Inc  
Project: Transfer Station-SPDES  
Client Sample ID: 001 Willets Pt Blvd (Dec)  
Lab Sample ID: Q3760-01

Date Collected: 12/02/25 13:30  
Date Received: 12/03/25  
SDG No.: Q3760  
Matrix: WATER  
% Solid: 0

| Parameter      | Conc. | Qua. | DF | MDL   | LOQ / CRQL | Units | Prep Date      | Date Ana.      | Ana Met.                   |
|----------------|-------|------|----|-------|------------|-------|----------------|----------------|----------------------------|
| Ammonia as N   | 2.90  | OR   | 1  | 0.030 | 0.10       | mg/L  | 12/04/25 14:00 | 12/05/25 11:29 | SM 4500-NH3<br>B plus G-21 |
| BOD5           | 207   |      | 1  | 0.20  | 2.00       | mg/L  |                | 12/04/25 11:25 | SM 5210 B-16               |
| Oil and Grease | 5.60  |      | 1  | 0.29  | 5.00       | mg/L  |                | 12/08/25 12:37 | 1664A                      |
| TSS            | 105   |      | 1  | 1.00  | 4.00       | mg/L  |                | 12/04/25 16:00 | SM 2540 D-20               |

Comments: \_\_\_\_\_

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

## Report of Analysis

Client: Tully Environmental, Inc  
Project: Transfer Station-SPDES  
Client Sample ID: 001 Willets Pt Blvd (Dec)DL  
Lab Sample ID: Q3760-01DL

Date Collected: 12/02/25 13:30  
Date Received: 12/03/25  
SDG No.: Q3760  
Matrix: WATER  
% Solid: 0

| Parameter    | Conc. | Qua. | DF | MDL   | LOQ / CRQL | Units | Prep Date      | Date Ana.      | Ana Met.                   |
|--------------|-------|------|----|-------|------------|-------|----------------|----------------|----------------------------|
| Ammonia as N | 2.70  | D    | 2  | 0.060 | 0.20       | mg/L  | 12/04/25 14:00 | 12/05/25 12:10 | SM 4500-NH3<br>B plus G-21 |

Comments: \_\_\_\_\_

U = Not Detected  
LOQ = Limit of Quantitation  
MDL = Method Detection Limit  
LOD = Limit of Detection  
D = Dilution  
Q = indicates LCS control criteria did not meet requirements  
H = Sample Analysis Out Of Hold Time

J = Estimated Value  
B = Analyte Found in Associated Method Blank  
\* = indicates the duplicate analysis is not within control limits.  
E = Indicates the reported value is estimated because of the presence of interference.  
OR = Over Range  
N = Spiked sample recovery not within control limits

## Report of Analysis

Client: Tully Environmental, Inc  
Project: Transfer Station-SPDES  
Client Sample ID: 002 35th Ave (Dec)  
Lab Sample ID: Q3760-02

Date Collected: 12/02/25 13:30  
Date Received: 12/03/25  
SDG No.: Q3760  
Matrix: WATER  
% Solid: 0

| Parameter      | Conc. | Qua. | DF | MDL   | LOQ / CRQL | Units | Prep Date      | Date Ana.      | Ana Met.                   |
|----------------|-------|------|----|-------|------------|-------|----------------|----------------|----------------------------|
| Ammonia as N   | 3.40  | OR   | 1  | 0.030 | 0.10       | mg/L  | 12/04/25 14:00 | 12/05/25 11:29 | SM 4500-NH3<br>B plus G-21 |
| BOD5           | 290   |      | 1  | 0.20  | 2.00       | mg/L  |                | 12/04/25 11:25 | SM 5210 B-16               |
| Oil and Grease | 7.10  |      | 1  | 0.29  | 5.00       | mg/L  |                | 12/08/25 12:37 | 1664A                      |
| TSS            | 131   |      | 1  | 1.00  | 4.00       | mg/L  |                | 12/04/25 16:00 | SM 2540 D-20               |

Comments: \_\_\_\_\_

U = Not Detected  
LOQ = Limit of Quantitation  
MDL = Method Detection Limit  
LOD = Limit of Detection  
D = Dilution  
Q = indicates LCS control criteria did not meet requirements  
H = Sample Analysis Out Of Hold Time

J = Estimated Value  
B = Analyte Found in Associated Method Blank  
\* = indicates the duplicate analysis is not within control limits.  
E = Indicates the reported value is estimated because of the presence of interference.  
OR = Over Range  
N = Spiked sample recovery not within control limits

## Report of Analysis

Client: Tully Environmental, Inc  
Project: Transfer Station-SPDES  
Client Sample ID: 002 35th Ave (Dec)DL  
Lab Sample ID: Q3760-02DL

Date Collected: 12/02/25 13:30  
Date Received: 12/03/25  
SDG No.: Q3760  
Matrix: WATER  
% Solid: 0

| Parameter    | Conc. | Qua. | DF | MDL   | LOQ / CRQL | Units | Prep Date      | Date Ana.      | Ana Met.                   |
|--------------|-------|------|----|-------|------------|-------|----------------|----------------|----------------------------|
| Ammonia as N | 3.30  | D    | 2  | 0.060 | 0.20       | mg/L  | 12/04/25 14:00 | 12/05/25 12:10 | SM 4500-NH3<br>B plus G-21 |

Comments: \_\_\_\_\_

U = Not Detected  
LOQ = Limit of Quantitation  
MDL = Method Detection Limit  
LOD = Limit of Detection  
D = Dilution  
Q = indicates LCS control criteria did not meet requirements  
H = Sample Analysis Out Of Hold Time

J = Estimated Value  
B = Analyte Found in Associated Method Blank  
\* = indicates the duplicate analysis is not within control limits.  
E = Indicates the reported value is estimated because of the presence of interference.  
OR = Over Range  
N = Spiked sample recovery not within control limits

## LAB CHRONICLE

|                 |                          |                   |                        |
|-----------------|--------------------------|-------------------|------------------------|
| <b>OrderID:</b> | Q3760                    | <b>OrderDate:</b> | 12/3/2025 10:53:00 AM  |
| <b>Client:</b>  | Tully Environmental, Inc | <b>Project:</b>   | Transfer Station-SPDES |
| <b>Contact:</b> | Dean Devoe               | <b>Location:</b>  | A11,VOA Lab            |

| LabID      | ClientID                       | Matrix | Test           | Method     | Sample Date       | Prep Date | Anal Date         | Received |
|------------|--------------------------------|--------|----------------|------------|-------------------|-----------|-------------------|----------|
| Q3760-01   | 001 Willets Pt Blvd<br>(Dec)   | WATER  |                |            | 12/02/25<br>13:30 | 12/04/25  |                   | 12/03/25 |
|            |                                |        | Ammonia        | SM4500-NH3 |                   |           | 12/05/25<br>11:29 |          |
|            |                                |        | BOD5           | SM5210 B   |                   |           | 12/04/25<br>11:25 |          |
|            |                                |        | Oil and Grease | 1664A      |                   |           | 12/08/25<br>12:37 |          |
|            |                                |        | TSS            | SM2540 D   |                   |           | 12/04/25<br>16:00 |          |
| Q3760-01DL | 001 Willets Pt Blvd<br>(Dec)DL | WATER  |                |            | 12/02/25<br>13:30 | 12/04/25  |                   | 12/03/25 |
|            |                                |        | Ammonia        | SM4500-NH3 |                   |           | 12/05/25<br>12:10 |          |
| Q3760-02   | 002 35th Ave (Dec)             | WATER  |                |            | 12/02/25<br>13:30 | 12/04/25  |                   | 12/03/25 |
|            |                                |        | Ammonia        | SM4500-NH3 |                   |           | 12/05/25<br>11:29 |          |
|            |                                |        | BOD5           | SM5210 B   |                   |           | 12/04/25<br>11:25 |          |
|            |                                |        | Oil and Grease | 1664A      |                   |           | 12/08/25<br>12:37 |          |
|            |                                |        | TSS            | SM2540 D   |                   |           | 12/04/25<br>16:00 |          |
| Q3760-02DL | 002 35th Ave (Dec)DL           | WATER  |                |            | 12/02/25<br>13:30 | 12/04/25  |                   | 12/03/25 |
|            |                                |        | Ammonia        | SM4500-NH3 |                   |           | 12/05/25<br>12:10 |          |