

Preparation Blank Summary

Client: Parkway Generation Operating LLC

SDG No.: Q3774

Project: Linden Generating Station - LRSA

Analyte	Units	Result	Acceptance Limits	Conc Qual	MDL	RDL	Analysis Date
Sample ID: BOD5	LB138103BL mg/L	< 0.2000	0.2000	U	0.20	2.0	12/04/2025
Sample ID: TSS	LB138118BL mg/L	1	2.0000	J	1	4	12/04/2025
Sample ID: COD	LB138124BL mg/L	< 5.0000	5.0000	U	1.5	10.0	12/05/2025