

Duplicate Sample Summary

Client: Parkway Generation Operating LLC	SDG No.: Q3774
Project: Linden Generating Station - LRSA	Sample ID: Q3760-02
Client ID: 002 35th Ave (Dec)DUP	Percent Solids for Spike Sample: 0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
TSS	mg/L	+/-5	131		133		1	1.51		12/04/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q3774
Project:	Linden Generating Station - LRSA	Sample ID:	Q3771-02
Client ID:	CompDUP	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
BOD5	mg/L	+/-20	87.4		86.0		1	1.61		12/04/2025

Duplicate Sample Summary

Client: Parkway Generation Operating LLC	SDG No.: Q3774
Project: Linden Generating Station - LRSA	Sample ID: Q3785-04
Client ID: WATER-TREATMEN DISCHARGEDUP	Percent Solids for Spike Sample: 0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
COD	mg/L	+/-20	1.50	U	1.50	U	1	0		12/05/2025

Duplicate Sample Summary

Client:	Parkway Generation Operating LLC	SDG No.:	Q3774
Project:	Linden Generating Station - LRSA	Sample ID:	Q3785-04
Client ID:	WATER-TREATMENT DISCHARGEMSD	Percent Solids for Spike Sample:	0

Analyte	Units	Acceptance Limit	Sample Result	Conc. Qualifier	Duplicate Result	Conc. Qualifier	Dilution Factor	RPD/ AD	Qual	Analysis Date
COD	mg/L	+/-20	48.2		47.1		1	2.31		12/05/2025