

## Report of Analysis

Client: Parkway Generation Operating LLC  
Project: Linden Generating Station - 402  
Client Sample ID: NGKO  
Lab Sample ID: Q3775-01

Date Collected: 12/03/25 13:35  
Date Received: 12/03/25  
SDG No.: Q3775  
Matrix: SOIL  
% Solid: 100

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Corrosivity	8.62	H	1	0	0	pH		12/04/25 09:00	9045D
Flash Point	142		1	0	0	o F		12/05/25 14:25	1010B
Reactive Cyanide	0.049	U	1	0.0083	0.049	mg/Kg	12/08/25 08:50	12/08/25 11:20	9012B
Reactive Sulfide	6.30	J	1	0.20	10.0	mg/Kg	12/04/25 09:05	12/04/25 12:51	9034

Comments: pH result reported at temperature 20.9 °C, Other method reference for flash point : Pensky-Martens Closed Cup Flash Point ASTM D 9

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

\* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N =Spiked sample recovery not within control limits