



SAMPLE DATA

A

B

C

Report of Analysis

Client: CHA Companies, Inc.
Project: NYSOMH Emergency Service
Client Sample ID: B2-W14-RM3088-SINK
Lab Sample ID: Q3841-01

Date Collected: 12/11/25 09:40
Date Received: 12/11/25
SDG No.: Q3841
Matrix: Water
% Solid: 0

| Parameter | Conc. | Qua. | DF | MDL | LOQ / CRQL | Units | Prep Date | Date Ana. | Ana Met. |
|-------------------|-------|------|----|-------|------------|-------|-----------|----------------|--------------------|
| Residual Chlorine | 0.15 | H | 1 | 0.023 | 0.10 | mg/L | | 12/11/25 16:26 | SM 4500-Cl G-11 |
| Turbidity | 0.90 | J | 1 | 0.15 | 1.00 | NTU | | 12/12/25 10:03 | SM 2130 B-20 |

Comments: _____

U = Not Detected
LOQ = Limit of Quantitation
MDL = Method Detection Limit
LOD = Limit of Detection
D = Dilution
Q = indicates LCS control criteria did not meet requirements
H = Sample Analysis Out Of Hold Time

J = Estimated Value
B = Analyte Found in Associated Method Blank
* = indicates the duplicate analysis is not within control limits.
E = Indicates the reported value is estimated because of the presence of interference.
OR = Over Range
N = Spiked sample recovery not within control limits

Report of Analysis

Client: CHA Companies, Inc.
Project: NYSOMH Emergency Service
Client Sample ID: B2-W14-RM3075-SINK
Lab Sample ID: Q3841-02

Date Collected: 12/11/25 09:45
Date Received: 12/11/25
SDG No.: Q3841
Matrix: Water
% Solid: 0

| Parameter | Conc. | Qua. | DF | MDL | LOQ / CRQL | Units | Prep Date | Date Ana. | Ana Met. |
|-------------------|-------|------|----|-------|------------|-------|-----------|----------------|--------------------|
| Residual Chlorine | 0.20 | H | 1 | 0.023 | 0.10 | mg/L | | 12/11/25 16:38 | SM 4500-Cl G-11 |
| Turbidity | 1.00 | J | 1 | 0.15 | 1.00 | NTU | | 12/12/25 10:06 | SM 2130 B-20 |

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

Report of Analysis

Client: CHA Companies, Inc.
Project: NYSOMH Emergency Service
Client Sample ID: B2-W14-LHDF
Lab Sample ID: Q3841-03

Date Collected: 12/11/25 09:50
Date Received: 12/11/25
SDG No.: Q3841
Matrix: Water
% Solid: 0

| Parameter | Conc. | Qua. | DF | MDL | LOQ / CRQL | Units | Prep Date | Date Ana. | Ana Met. |
|-------------------|-------|------|----|-------|------------|-------|-----------|----------------|--------------------|
| Residual Chlorine | 0.023 | HU | 1 | 0.023 | 0.10 | mg/L | | 12/11/25 16:41 | SM 4500-Cl G-11 |
| Turbidity | 1.48 | | 1 | 0.15 | 1.00 | NTU | | 12/12/25 10:09 | SM 2130 B-20 |

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

Report of Analysis

Client: CHA Companies, Inc.
Project: NYSOMH Emergency Service
Client Sample ID: B2-W14-RM3055-RH-SINK
Lab Sample ID: Q3841-04

Date Collected: 12/11/25 09:55
Date Received: 12/11/25
SDG No.: Q3841
Matrix: Water
% Solid: 0

| Parameter | Conc. | Qua. | DF | MDL | LOQ / CRQL | Units | Prep Date | Date Ana. | Ana Met. |
|-------------------|-------|------|----|-------|------------|-------|-----------|----------------|--------------------|
| Residual Chlorine | 0.041 | HJ | 1 | 0.023 | 0.10 | mg/L | | 12/11/25 16:44 | SM 4500-Cl G-11 |
| Turbidity | 0.53 | J | 1 | 0.15 | 1.00 | NTU | | 12/12/25 10:12 | SM 2130 B-20 |

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

Report of Analysis

Client: CHA Companies, Inc.
Project: NYSOMH Emergency Service
Client Sample ID: B2-W14-EW
Lab Sample ID: Q3841-05

Date Collected: 12/11/25 10:05
Date Received: 12/11/25
SDG No.: Q3841
Matrix: Water
% Solid: 0

| Parameter | Conc. | Qua. | DF | MDL | LOQ / CRQL | Units | Prep Date | Date Ana. | Ana Met. |
|-------------------|-------|------|----|-------|------------|-------|-----------|----------------|--------------------|
| Residual Chlorine | 0.023 | HU | 1 | 0.023 | 0.10 | mg/L | | 12/11/25 16:47 | SM 4500-Cl G-11 |
| Turbidity | 0.65 | J | 1 | 0.15 | 1.00 | NTU | | 12/12/25 10:15 | SM 2130 B-20 |

Comments: _____

U = Not Detected
LOQ = Limit of Quantitation
MDL = Method Detection Limit
LOD = Limit of Detection
D = Dilution
Q = indicates LCS control criteria did not meet requirements
H = Sample Analysis Out Of Hold Time

J = Estimated Value
B = Analyte Found in Associated Method Blank
* = indicates the duplicate analysis is not within control limits.
E = Indicates the reported value is estimated because of the presence of interference.
OR = Over Range
N = Spiked sample recovery not within control limits

Report of Analysis

Client: CHA Companies, Inc.
Project: NYSOMH Emergency Service
Client Sample ID: B2-W14-RM3056-SINK
Lab Sample ID: Q3841-06

Date Collected: 12/11/25 10:10
Date Received: 12/11/25
SDG No.: Q3841
Matrix: Water
% Solid: 0

| Parameter | Conc. | Qua. | DF | MDL | LOQ / CRQL | Units | Prep Date | Date Ana. | Ana Met. |
|-------------------|-------|------|----|-------|------------|-------|-----------|----------------|--------------------|
| Residual Chlorine | 0.023 | HU | 1 | 0.023 | 0.10 | mg/L | | 12/11/25 16:57 | SM 4500-Cl G-11 |
| Turbidity | 0.44 | J | 1 | 0.15 | 1.00 | NTU | | 12/12/25 10:18 | SM 2130 B-20 |

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

Report of Analysis

Client: CHA Companies, Inc.
Project: NYSOMH Emergency Service
Client Sample ID: B2-W14-RM3073-SINK
Lab Sample ID: Q3841-07

Date Collected: 12/11/25 10:15
Date Received: 12/11/25
SDG No.: Q3841
Matrix: Water
% Solid: 0

| Parameter | Conc. | Qua. | DF | MDL | LOQ / CRQL | Units | Prep Date | Date Ana. | Ana Met. |
|-------------------|-------|------|----|-------|------------|-------|-----------|----------------|--------------------|
| Residual Chlorine | 0.052 | HJ | 1 | 0.023 | 0.10 | mg/L | | 12/11/25 17:00 | SM 4500-Cl G-11 |
| Turbidity | 0.43 | J | 1 | 0.15 | 1.00 | NTU | | 12/12/25 10:21 | SM 2130 B-20 |

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

LAB CHRONICLE

| | | | |
|-----------------|---------------------|-------------------|--------------------------|
| OrderID: | Q3841 | OrderDate: | 12/11/2025 2:15:00 PM |
| Client: | CHA Companies, Inc. | Project: | NYSOMH Emergency Service |
| Contact: | Carrie Robinson | Location: | D41 |

| LabID | ClientID | Matrix | Test | Method | Sample Date | Prep Date | Anal Date | Received |
|----------|---------------------------|--------|-------------------|-------------|-------------------|-----------|-------------------|----------|
| Q3841-01 | B2-W14-RM3088-SIN K | Water | Residual Chlorine | SM4500 Cl G | 12/11/25 09:40 | | 12/11/25 16:26 | 12/11/25 |
| | | | Turbidity | SM2130 B | | | 12/12/25 10:03 | |
| Q3841-02 | B2-W14-RM3075-SIN K | Water | Residual Chlorine | SM4500 Cl G | 12/11/25 09:45 | | 12/11/25 16:38 | 12/11/25 |
| | | | Turbidity | SM2130 B | | | 12/12/25 10:06 | |
| Q3841-03 | B2-W14-LHDF | Water | Residual Chlorine | SM4500 Cl G | 12/11/25 09:50 | | 12/11/25 16:41 | 12/11/25 |
| | | | Turbidity | SM2130 B | | | 12/12/25 10:09 | |
| Q3841-04 | B2-W14-RM3055-RH- SINK | Water | Residual Chlorine | SM4500 Cl G | 12/11/25 09:55 | | 12/11/25 16:44 | 12/11/25 |
| | | | Turbidity | SM2130 B | | | 12/12/25 10:12 | |
| Q3841-05 | B2-W14-EW | Water | Residual Chlorine | SM4500 Cl G | 12/11/25 10:05 | | 12/11/25 16:47 | 12/11/25 |

LAB CHRONICLE

| | | | | | | | |
|----------|------------------------|-------|-------------------|-------------|-------------------|-------------------|----------|
| Q3841-06 | B2-W14-RM3056-SIN K | Water | Turbidity | SM2130 B | 12/12/25 10:15 | 12/11/25 10:10 | 12/11/25 |
| | | | Residual Chlorine | SM4500 Cl G | 12/11/25 16:57 | | |
| | | | Turbidity | SM2130 B | 12/12/25 10:18 | | |
| Q3841-07 | B2-W14-RM3073-SIN K | Water | | | | 12/11/25 10:15 | 12/11/25 |
| | | | Residual Chlorine | SM4500 Cl G | 12/11/25 17:00 | | |
| | | | Turbidity | SM2130 B | 12/12/25 10:21 | | |