



SAMPLE DATA

A

B

C

Report of Analysis

Client: CHA Companies, Inc.
Project: NYSOMH Emergency Service
Client Sample ID: B2-W14-RM3088-SINK
Lab Sample ID: Q3841-01

Date Collected: 12/11/25 09:40
Date Received: 12/11/25
SDG No.: Q3841
Matrix: Water
% Solid: 0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.15	H	1	0.023	0.10	mg/L		12/11/25 16:26	SM 4500-Cl G-11
Turbidity	0.90	J	1	0.15	1.00	NTU		12/12/25 10:03	SM 2130 B-20

Comments: _____

U = Not Detected
LOQ = Limit of Quantitation
MDL = Method Detection Limit
LOD = Limit of Detection
D = Dilution
Q = indicates LCS control criteria did not meet requirements
H = Sample Analysis Out Of Hold Time

J = Estimated Value
B = Analyte Found in Associated Method Blank
* = indicates the duplicate analysis is not within control limits.
E = Indicates the reported value is estimated because of the presence of interference.
OR = Over Range
N = Spiked sample recovery not within control limits

Report of Analysis

Client: CHA Companies, Inc.
Project: NYSOMH Emergency Service
Client Sample ID: B2-W14-RM3075-SINK
Lab Sample ID: Q3841-02

Date Collected: 12/11/25 09:45
Date Received: 12/11/25
SDG No.: Q3841
Matrix: Water
% Solid: 0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.20	H	1	0.023	0.10	mg/L		12/11/25 16:38	SM 4500-Cl G-11
Turbidity	1.00	J	1	0.15	1.00	NTU		12/12/25 10:06	SM 2130 B-20

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

Report of Analysis

Client: CHA Companies, Inc.
Project: NYSOMH Emergency Service
Client Sample ID: B2-W14-LHDF
Lab Sample ID: Q3841-03

Date Collected: 12/11/25 09:50
Date Received: 12/11/25
SDG No.: Q3841
Matrix: Water
% Solid: 0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.023	HU	1	0.023	0.10	mg/L		12/11/25 16:41	SM 4500-Cl G-11
Turbidity	1.48		1	0.15	1.00	NTU		12/12/25 10:09	SM 2130 B-20

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

Report of Analysis

Client: CHA Companies, Inc.
Project: NYSOMH Emergency Service
Client Sample ID: B2-W14-RM3055-RH-SINK
Lab Sample ID: Q3841-04

Date Collected: 12/11/25 09:55
Date Received: 12/11/25
SDG No.: Q3841
Matrix: Water
% Solid: 0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.041	HJ	1	0.023	0.10	mg/L		12/11/25 16:44	SM 4500-Cl G-11
Turbidity	0.53	J	1	0.15	1.00	NTU		12/12/25 10:12	SM 2130 B-20

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

Report of Analysis

Client: CHA Companies, Inc.
Project: NYSOMH Emergency Service
Client Sample ID: B2-W14-EW
Lab Sample ID: Q3841-05

Date Collected: 12/11/25 10:05
Date Received: 12/11/25
SDG No.: Q3841
Matrix: Water
% Solid: 0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.023	HU	1	0.023	0.10	mg/L		12/11/25 16:47	SM 4500-Cl G-11
Turbidity	0.65	J	1	0.15	1.00	NTU		12/12/25 10:15	SM 2130 B-20

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

Report of Analysis

Client: CHA Companies, Inc.
Project: NYSOMH Emergency Service
Client Sample ID: B2-W14-RM3056-SINK
Lab Sample ID: Q3841-06

Date Collected: 12/11/25 10:10
Date Received: 12/11/25
SDG No.: Q3841
Matrix: Water
% Solid: 0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.023	HU	1	0.023	0.10	mg/L		12/11/25 16:57	SM 4500-Cl G-11
Turbidity	0.44	J	1	0.15	1.00	NTU		12/12/25 10:18	SM 2130 B-20

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

Report of Analysis

Client: CHA Companies, Inc.
Project: NYSOMH Emergency Service
Client Sample ID: B2-W14-RM3073-SINK
Lab Sample ID: Q3841-07

Date Collected: 12/11/25 10:15
Date Received: 12/11/25
SDG No.: Q3841
Matrix: Water
% Solid: 0

Parameter	Conc.	Qua.	DF	MDL	LOQ / CRQL	Units	Prep Date	Date Ana.	Ana Met.
Residual Chlorine	0.052	HJ	1	0.023	0.10	mg/L		12/11/25 17:00	SM 4500-Cl G-11
Turbidity	0.43	J	1	0.15	1.00	NTU		12/12/25 10:21	SM 2130 B-20

Comments: _____

U = Not Detected

LOQ = Limit of Quantitation

MDL = Method Detection Limit

LOD = Limit of Detection

D = Dilution

Q = indicates LCS control criteria did not meet requirements

H = Sample Analysis Out Of Hold Time

J = Estimated Value

B = Analyte Found in Associated Method Blank

* = indicates the duplicate analysis is not within control limits.

E = Indicates the reported value is estimated because of the presence of interference.

OR = Over Range

N = Spiked sample recovery not within control limits

LAB CHRONICLE

OrderID:	Q3841	OrderDate:	12/11/2025 2:15:00 PM
Client:	CHA Companies, Inc.	Project:	NYSOMH Emergency Service
Contact:	Carrie Robinson	Location:	D41

LabID	ClientID	Matrix	Test	Method	Sample Date	Prep Date	Anal Date	Received
Q3841-01	B2-W14-RM3088-SIN K	Water	Residual Chlorine	SM4500 CI G	12/11/25 09:40		12/11/25 16:26	12/11/25
			Turbidity	SM2130 B			12/12/25 10:03	
Q3841-02	B2-W14-RM3075-SIN K	Water	Residual Chlorine	SM4500 CI G	12/11/25 09:45		12/11/25 16:38	12/11/25
			Turbidity	SM2130 B			12/12/25 10:06	
Q3841-03	B2-W14-LHDF	Water	Residual Chlorine	SM4500 CI G	12/11/25 09:50		12/11/25 16:41	12/11/25
			Turbidity	SM2130 B			12/12/25 10:09	
Q3841-04	B2-W14-RM3055-RH- SINK	Water	Residual Chlorine	SM4500 CI G	12/11/25 09:55		12/11/25 16:44	12/11/25
			Turbidity	SM2130 B			12/12/25 10:12	
Q3841-05	B2-W14-EW	Water	Residual Chlorine	SM4500 CI G	12/11/25 10:05		12/11/25 16:47	12/11/25

LAB CHRONICLE

Q3841-06	B2-W14-RM3056-SIN K	Water	Turbidity	SM2130 B	12/12/25 10:15	12/11/25 10:10	12/11/25
			Residual Chlorine	SM4500 Cl G	12/11/25 16:57		
			Turbidity	SM2130 B	12/12/25 10:18		
Q3841-07	B2-W14-RM3073-SIN K	Water				12/11/25 10:15	12/11/25
			Residual Chlorine	SM4500 Cl G	12/11/25 17:00		
			Turbidity	SM2130 B	12/12/25 10:21		